

P.L. B. FYI

**TOWN OF ACTON
INTERDEPARTMENTAL COMMUNICATION**

Date: June 22, 2006

To: Roland Bartl
Kristin Alexander

From: Engineering Department
Bruce M. Stamski, P.E., Town Engineer/Director of Public Works

Subject: Robbins Mill- drainage revisions

This office , after several inspections, determined the drainage for Blueberry Path needed improvement. Water is flowing overland from the common land into the gutters for long time periods after rainfall ends. In addition there are signs that subsurface water may be bypassing the installed subdrains causing damage to the road surface.

We informed Pulte Homes of our concerns and had a meeting with them and their engineers. They have prepared a plan detailing additional swales, catchbasins and sub drainage dated 6/13/06. We have reviewed this plan and found their proposal to rectify this problem to be sound. We believe this plan should be accepted as a "redline" change.

By copy of this communication, I am requesting Pulte Homes to supply us with 4 copies of the plan stamped by their engineer.

Sincerely,



Bruce M. Stamski, P. E.
Town Engineer/Director of Public Works

Cc Pulte Homes

