

9/14/09

18



TOWN OF ACTON
472 Main Street
Acton, Massachusetts, 01720
Telephone (978) 264-9628
Fax (978) 264-9630

Engineering Department

INTERDEPARTMENTAL COMMUNICATION

To: Board of Selectmen

Date: September 2, 2009

Revised: September 9, 2009

From: Engineering Department

Subject: National Grid – Gas Main Petition – Summer Street – Willow St to Central St

We reviewed the petition from National Grid to install approximately 725 feet, more or less, of 6-inch gas main from the existing 2-inch gas main on Willow Street to the existing 4-inch gas main on Central Street. The new 6-inch gas main will replace and abandon the existing 2-inch main in Summer Street at this location. National Grid has attached a sketch showing the proposed work. The DPW has been working on improvements to the intersection of Central Street and Summer Street. Prior to the start of this work, we would like to meet with National Grid to discuss the proposed location for the gas main by Central Street to coordinate this project with our intersection improvement project. **We revised our original memo based upon our discussion with Keith Lincoln of National Grid.**

As part of this work, we request the following items from National Grid:

1. Meet and discuss this project in relation to the Town's intersection improvement project at Central Street.
National Grid has agreed to meet with the Town in order to coordinate these construction projects.
2. Submit a new dig-safe number for the Permit to Construct within a Public Way that we have in the Engineering office.
National Grid will submit their Dig-Safe number to the Engineering office prior to the start of construction.

We do not foresee any problems with granting this petition. If you have any questions, or need additional information, please let us know.

PETITION OF NATIONALGRID FOR GAS MAIN LOCATIONS

Town of Acton / Board of Selectmen:-

The Nationalgrid hereby respectfully requests your consent to the locations of mains as hereinafter described for the transmission and distribution of gas in and under the following public streets, lanes, highways, and places of the **Town of Acton** and of the pipes, valves, governors, manholes and other structures, fixtures and appurtenances designed or intended to protect or operate said mains and accomplish the objects of said Company; and the digging up and opening the ground to lay or place same:

To install and maintain approximately 725 feet, more or less of 6 inch gas main in Summer Street Acton.

From the existing 2 inch gas main at Willow Street Easterly to the existing 4 inch gas main at Central Street. All of which to replace and abandon the existing 2 inch gas main in Summer Street, Acton.

DATE August 28, 2009

BY 
Dennis K. Regan
Permit Representative

ORDER FOR GAS MAIN LOCATION

Town of Acton / Board of Selectmen:

IT IS HEREBY ORDERED that the locations of the mains of the Nationalgrid for the transmission and distribution of gas in and under the public streets, lanes, highways, and places of the **Town of Acton** substantially as described in the petition dated **August 28, 2009** attached hereto and hereby made a part hereof, and of the pipes, valves, governors, manholes and other structures, fixtures and appurtenances designed or intended to protect or operate said mains and/or accomplish the objects of said Company, and the digging up and opening the ground to lay or place same, are hereby consented to and approved.

The said Nationalgrid shall comply with all applicable provisions of law and ordinances of the **Town of Acton** applicable to the enjoyment of said locations and rights.

Dated this _____ day of _____, 20 ____.

I hereby certify that the foregoing order was duly adopted by the _____ of the City of _____, MA on the _____ day of _____ 20 ____.

BY _____


Title

MN # 144-8502-640978

**RETURN ORIGINAL TO THE PERMIT SECTION
Nationalgrid
52 SECOND AVENUE, WALTHAM, MA 02451
RETAIN DUPLICATE FOR YOUR RECORDS**

SUC Code	Owner Name	Address	City State	Zip Code	Phone
101	METZGER BRUCE P	8 SUMMER ST	ACTON MA	01720-2708	9782638674
101	MADDEN PAUL B JR	12 SUMMER ST	ACTON MA	01720-2708	9782631902
101	CHAMPOUX KEITH R	13 SUMMER ST	ACTON MA	01720-2707	9786350394
101	SWEENEY KATHRYN R	19 SUMMER ST	ACTON MA	01720-2707	9782635462
101	WALLACE DAVID A	20 SUMMER ST	ACTON MA	01720-2708	9782644449
132	PORETTA YVONNE E	23 SUMMER ST	ACTON MA	01720-2707	9782630959
101	MARIE CAROL MARGUERIT	24 SUMMER ST	ACTON MA	01720-2708	0
101	TUCKER DAVID J	33 SUMMER ST	ACTON MA	01720-2220	9782639605
101	COMMERFO RD JANINE	41 SUMMER ST	ACTON MA	01720-2220	0
101	BETTEZ RYAN	46 SUMMER ST	ACTON MA	01720-2221	9782637711
101	WESSEL MARK	49 SUMMER ST	ACTON MA	01720-2253	0
101	ALUSIC- VALDEANE ANDREA	56 SUMMER ST	ACTON MA	01720-2221	0
101	NEAGLE GEORGE ELDRED JR	66 SUMMER ST	ACTON MA	01720-2221	9782634998
101	BOWERS FREDERICK	186 CENTRAL ST	ACTON MA	01720-2803	9786359807
101	PORETTA YVONNE E	54 WILLOW ST	ACTON MA	01720-2868	9782630959
101	CARROLL KEVIN	60 WILLOW ST	ACTON MA	01720-2710	9787429949
101	GLANNON ANN M	63 WILLOW ST	ACTON MA	01720-2709	9782632823


- PRESSURE GAUGES ARE REQUIRED AT ALL MAINS FOR ALL TIE-INS. REFER TO GCN-7010 PROCEDURE.
- CHECK ELECTRONIC MAPPING SYSTEM FOR MOST CURRENT MAPPING INFORMATION.



ENGINEERING DESIGN - Proposed Scope of Work

ACE105 REINFORCEMENT - Summer St, Acton

As part of ACE105 Project, relay approx 725' of 2" 60psig CS main in Summer St with 6" 60psig PL main from the 2" 60psig PL gas main in the intersection of Willow St and Summer St to the intersection of Central St and Summer St.



NOTE: The location of surface and underground objects shown are not warranted to be correct.

ENGINEER	JPS	SIZE	6"
DATE	08/26/2009	MATERIAL	PL
LENGTH	725'	PRESSURE	60psig
SECTIONALS	XXXX1234	WORK ORDER #	640978

ArcFM

nationalgrid