

Addendum No. 3
June 9, 2010
Town of Acton
Main Street Sidewalk Project

- The Town has changed the date of the Bid Opening for the Main Street Sidewalk Construction Contract #6/10/2010 – 919.
 - The original Bid Opening was scheduled for Thursday, June 10, 2010 at 10 AM.
 - The new date for the Bid Opening is scheduled for to **Friday, June 25, 2010 at 10 AM.**

- The proposed sidewalk between STATION 26+70.47 and STATION 41+70 will be constructed with a **Porous Asphalt Mix** instead of the Type 1 Bituminous Concrete Pavement as specified on the Plans and in the Bid Documents. The Porous Asphalt Mix shall be applied in 2 courses. Each course shall be 1.5 inches thick to provide an overall porous asphalt mix thickness of 3 inches. The Porous Asphalt Design Mix shall conform to the material specifications as listed in the attached mix design.


Porous Asphalt Mix Design
PJ Keating – Lunenburg, MA

Sieve Size	Percent Passing	Control Points
¾"	100	100
½"	93	85-100
3/8"	65	55-75
#4	18	10-25
#8	7	5-10
#16	6	
#30	5	
#50	4	
#100	3	
#200	3.0	2-4
Percent PG 64-28	6.0	6.0-6.5

Designed using UNHSC Design Specifications for Porous Asphalt Pavement

Material	Source	Percentage
½" Stone	P.J. Keating Co. Lunenburg, MA.	36.0
3/8" Stone	P.J. Keating Co. Lunenburg, MA.	54.0
Washed Screenings	P.J. Keating Co. Lunenburg, MA.	0.0
1/2" RAP	P.J. Keating Co. Lunenburg, MA.	10.0
PG BINDER		
PG 64-28 Binder	Pike Industries – Newington NH. Aggregate Industries- Everett, MA. Hudson Terminal – Providence RI.	
SBR Polymer Compound	Rub-R-Roads, Inc. – Kent, OH	1.5% by weight of bitumen.
BoniFibers	Kapejo, Inc. – New Castle, DE	5 lbs per ton of asphalt mix.

Approved By:


 Benjamin Stocking
 Asst. Quality Assurance Manager



TOWN OF ACTON
472 Main Street
Acton, Massachusetts 01720
Telephone (978) 264-9628
Fax (978) 264-9630

Acknowledgement of Receipt for Addendum #3

**Re: Main Street Sidewalk Construction
from Post Office Square to Great Road (Route 2A/119)
Acton, Massachusetts
Contract # 6/10/2010 - 919**

I acknowledged that I have received a copy of Addendum #3 for the above-referenced Contract.

Please sign this acknowledgement form below and return it to the Town of Acton Engineering Department in the self-addressed stamped envelope. Thank you

Signed: _____

(date)