



ALLEN & MAJOR  
ASSOCIATES, INC.

100 Commerce Way  
P.O. Box 2118  
Woburn, MA 01888-0118  
Tel: (781) 935-6889  
Fax: (781) 935-2896

August 16, 2010

Ken Kozik, Chairman  
Members of the Board  
Acton Board of Appeals  
472 Main Street  
Acton, MA 01720

RE: A&M Project #1298-08  
McCarthy Village II  
Acton, MA 01720  
Comprehensive Permit

Dear Chairman Kozik and Board Members:

Allen & Major Associates, on behalf of The Acton Housing Authority respectfully submits a review response memo regarding the McCarthy Village II, Comprehensive Permit comments and concerns raised by the Town of Acton Engineering Department. This letter is prepared in response to a memo prepared by Town of Acton Engineering Department to your office dated July 20, 2010. The comments are based on the following submitted materials:

- "Comprehensive Permit Plans for McCarthy Village II" prepared by Allen & Major Associates, Inc., dated June 25, 2010.
- "McCarthy Village II, Site Development Drainage Report" prepared by Allen & Major Associates, Inc., dated June 1, 2010.

1. The snow storage provided by the applicant appears to runoff the site without treatment.

*Response: Snow melt will sheet flow to the closed drainage system which in turn, discharges to an underground infiltration system. The underground infiltration system incorporates an isolator row which is designed to "treat" the stormwater prior to infiltrating back into the aquifer. As noted in the Massachusetts Department of Environmental Protections (MassDEP) Stormwater Regulations, underground infiltration systems provide 80% TSS removal.*

2. The applicant states that rooftop runoff will be directed toward the five dry wells; however, it is not clear how the rooftop runoff from buildings D, E, and F will reach the drywells.

*Response: Buildings D, E and F will not be routed to drywell structures due to the subsurface soil conditions. These buildings are in an area of major cuts and it is anticipated that the underlying soils will be restrictive to infiltration. The underground infiltration system has been oversized to compensate for these buildings not being able to mitigate for their stormwater runoff individually.*

3. The applicant should provide the town a with pre and post development watershed plan.

*Response: McCarthy Village II, Site Development Drainage Report" dated June 1, 2010 included pre and post development watershed plans. Additional plans area attached to this response.*

4. While it appears that an SU-30 truck movement works with our turning templates, we defer comments to the Fire Department regarding the movement of a fire truck on this site.

*Response: During development meetings with various Town departments, the Fire Department has indicated that it is comfortable with the site layout in regard to truck movement.*

5. The roadway pavement detail shows a 6" gravel base. Acton requires a 12" base.

*Response: The pavement detail has been revised to reflect a 12" base course per Acton standards.*

6. The sidewalk detail shows a 2-1/2" pavement thickness and a 6" gravel base. Acton requires a 3" pavement thickness and a 6" gravel base. The gravel base is to be applied in two 3"-in courses.

*Response: The sidewalk detail has been revised to reflect two, 3-inch gravel base course lifts with a 3" pavement thickness per Acton standards.*

7. Acton requires shaped inverts on drain manholes. The drain manhole detail does not call this out.

*Response: The drain manhole detail has been revised to call out shaped inverts on all drain manhole structures.*

8. The site is adjacent to town owned land with park trails. The applicant could show a trail connection connecting this development with the existing trails.

*Response: The Acton Housing Authority will work with the Town on incorporating walking trails from the subject parcel to Town owned land as requested, provided funds are available.*

9. The "Possible Future Play Area" could be constructed along with the rest of the site as an amenity for the children.

*Response: The Acton Housing Authority will work with the Town on incorporating the "Possible Future Play Area" as suggested, provided funds are available.*

10. The plan shows a curb on the handicap ramp where there should be none.

*Response: The plans have been revised to indicate a flush curb with adjacent curbing transitioning to a flush condition.*

11. The applicant should relocate the hydrant at the end of the road. It is located in the snow storage area and would be obstructed during the winter.

*Response: The fire hydrant at the end of the site driveway has been relocated outside of the snow storage area and will be accessible during the winter months.*

12. An as-built plan will be required prior to obtaining a building permit.

*Response: An as-built plan will be provided prior to the issuance of a Certificate of Occupancy.*

13. The applicant should be sure the drain outlet pitches toward the wetland. The applicant should avoid flooding of the abutters.

*Response: There are no wetland resources on site however the proposed stormwater management system does provide positive drainage to the lowest point on the site where stormwater currently discharges off the property. As noted in the Drainage Report the proposed stormwater management system mitigates runoff over the existing conditions baseline so no anticipated flooding of the abutters is anticipated.*

14. The applicant should show a No Parking sign at the end of the truck turn-around.

*Response: A "No Parking" sign at the end of the truck turn-around has been incorporated into the design plans as requested.*

If you have any questions or comments please do not hesitate to contact me.

Very truly yours,

ALLEN & MAJOR ASSOCIATES, INC.



Timothy J. Williams, P.E.  
Vice President