

From: [Robert Craig](#)
To: [Board of Appeals](#)
Cc: [Planning Department](#); [Engineering Department](#); [Kevin Lyons](#)
Subject: Comprehensive Permit-26 3 Great Road-The Meadows at Acton
Date: Friday, May 11, 2012 3:42:51 PM

Please be advised that I have reviewed the site plans for this project and comments by the Engineering Department and have viewed the proposed site. I would concur with the Engineering Department relative to the following specific items noted in their memo.

1. It appears that turning radii for an SU-30 vehicle is adequate.
2. The applicant should consult with this department as there are no fire alarm call boxes shown. In addition, the spacing between the hydrants is excessive and should not exceed 500 feet in distance between hydrants. In addition there should be a hydrant at the entrance to this project. The applicant should consult with this department in this regard.
3. I would concur with Item #3 of the Engineering Department.

Robert C. Craig
Acton Fire Department
978-929-7414
978-266-2885(FAX)