

DESIGN REVIEW COMMENT AND RESOLUTION FORM



[Handwritten Signature]

PROJECT NO.: 604531

DESCRIPTION: Maynard - Acton - Assabet River Rail Trail

DESIGNER: AECOM

SUBMITTAL: 25% Resubmission

REVIEW SECTION: Complete Streets Engineer (CSE)

DATE: April 26, 2013

REVIEWER NAME: Luciano Rabito, P.E.

NO.	SHEET OR ITEM	COMMENT	INITIAL ACTION	RESPONSE	QC REVIEW INITIAL	FINAL ACTION VERIFIED
COMPLETED BY REVIEWER			COMPLETED BY DESIGNER			BY REVIEWER
1	40	D11-1 signs are not preferred. As this is a Named Route and there appears to be a Trail Sign available that should be used instead.				
2	45	Revise Path Crossing detail as shown on plan.				
3	45	Trail head islands show have pavement markings around them to make them more visible (See Plan)				
4	45	Provide grading plan for all wheelchair ramps for next submission				
5	30	Provide detail for motion flashing warning beacon.				
6	General	Adjust title block on all sheets (from sheet 3 on)				
7	General	In areas where the path crosses a drive way (e.g. p.24) the right of way should given to the path so a detail should be added.				
8	General	At locations where the path crosses near other side streets warning signs need to be considered on a location by location basis (e.g. P.16, 20)				
9	17	The bridge ends are considered obstruction so bike rails should tie into them then taper away beyond the 5 foot limit.				
10	14&15	The way the ramps line up crossing Sudbury Street need to be improved. (Sta. 51+00) WCR-10 could be turned more perpendicular to Sudbury Street and WCR-9 moved south a bit to line up better with WCR-10				
11	12	The brick paver walk is referenced as WCR-7. If considered a ramp it will need to be ADA compliant which means cement concrete and tactile warning panel. A brick band may be installed to highlight it.				
12	11	The two ramps near station 34+00 and the driveway could be combined as one with signage directing the ARRT users to the right.				
13	General	It would be helpful to show limits of wood rail fence by station on the construction plans.				
	Consultant Score: 7					

COLUMN "NO." PREFIX FOR COMMENT NO'S - PLANS =P, SPEC. PROVS=S, EST.=E, CALC BOOK=C, BRIDGE CALCS=D, OTHER = O
"ACTION" A=WILL INCORPORATE, B=WILL EVALUATE, C=DELETE COMMENT