



# Water Supply District of Acton

---

693 MASSACHUSETTS AVENUE  
P.O. BOX 953  
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107

FAX (978) 264-0148

DATE: 9/3/2013

TO: Town of Acton Planning Department

FROM: Chris Allen, District Manager

RE: Comments on CVS/400 Massachusetts Avenue

1. The proposed development will require >5,000 Gallons-per-day (GPD), and/or a connection to the existing water main >2", the owner, or owner's representative, must submit a "Water Impact Report" per Acton Water District (AWD) "*Rules & Regulations*".
2. The new 8" water main connection running from Massachusetts Ave to the new building should be moved to the East side of the building to shorten the extension for maintenance of domestic water quality. Either that, or a domestic water service, separate from the fire sprinkler line should be run on the East side of the building from Massachusetts Ave.
3. The existing domestic water service must be abandoned in Massachusetts Ave/Rt 111 by turning off the Corporation Stop valve at the existing 8" water main.
4. To minimize water irrigation needs, instead of sod over 4" of topsoil, AWD recommends 6" of topsoil with a minimum organic content of 10%.
5. All water mains, services, appurtenances and installation of such must comply with AWD specifications. (Hard copy may be picked up at AWD main office)
6. A proposed "As-Built" plan of the water infrastructure must be submitted, reviewed and approved by AWD prior to any installation of said infrastructure.
7. A final "As-Built" plan denoting exact locations of all water infrastructure will be submitted by the contractor in hard copy and .pdf format prior to filling of any water mains for pressure test or disinfection per AWD specifications.

Respectfully submitted

Chris Allen  
District Manager