

TOWN OF ACTON
472 Main Street
Acton, Massachusetts, 01720
Telephone (978) 264-9628
Fax (978) 264-9630

Engineering Department

INTERDEPARTMENTAL COMMUNICATION

To: Planning Department

Date: October 31, 2013

From: Engineering Department

**Subject: Wireless Communication Facility Special Permit – 5 Craig Road
SBA Towers II, LLC**

We have reviewed the above-mentioned plans for 5 Craig Road dated December 2, 2009 with a revision date of October 16, 2013 and have the following comments:

1. The contractor will be required to apply for a Permit to Construct within a Public Way for any work shown in the right of way for Craig Road.
2. The applicant has no proposal for a sidewalk in conjunction with this project. There are no sidewalks on Craig Road.
3. The 11"x17" plans provided by the applicant have been sized to fit the paper size and therefore are not to scale. We had a comment in our last memo about the scales on some of the plans being incorrect. On the previous submission dated June 10, 2013 for sheets C-1A and C-1B, the correct scales were 50 and 20 scale respectively.
4. Due to the plans not being able to be reproduced at a correct scale, we cannot verify the maneuverability of a fire trunk on site. On the previous submission, an SU-30 vehicle couldn't enter the proposed driveway heading north on Craig Road or maneuver within the site. The site appears to be unchanged from the previous submission.