

Date... JAN. 24, 1991

Permit No. 91-8

TOWN OF ACTON

APPLICATION FOR PERMIT TO CONSTRUCT WITHIN A PUBLIC WAY

This application must be submitted not less than five (5) days prior to any Construction within a public way.

Notice 24 hours in advance of any construction must be given to the Town Engineer.

1. Permittee: BOSTON GAS Co. Address: 66 COMM. AVE. REAR
- 1A. Telephone #: 369-8171 - 369-4775
2. Location of Proposed Construction: 1000 MAIN ST. NEAR POLE #338
3. Purpose of Construction: TO INSTALL NEW GAS SERVICE.
4. Length of Cut: 30'
5. Width of Cut: 2'
6. Width of Existing Pavement: 30'
7. Type of Existing Roadway Surface: ASPHALT Type of Curb: NONE
8. Type of Existing Sidewalk Surface: NONE Type of Shoulder: GRAVEL
9. Date of Street Opening: From ASAP To
10. For Work Involving Excavations: Dig Safe Number 910A1172

I, the undersigned, hereby declare that I have read and agree to the Town of Acton Specifications for Regulating Construction with Public Ways dated August 3, 1982. I have deposited the required bond with the Town of Acton, and I covenant and agree that the Town may deduct from this amount the cost of repairs to the road surface, curbs, shoulders, walls or other features within the right-of-way including replacing bounds if not completed by me to the satisfaction of the Town Engineer within the specified time.

Special Instructions:

Signature of Applicant

Mr. S. Jacto

INSP. 2/26/91 DR.

*ATTEMPT TO TUNNEL UNDER ROAD
NOT SUCCESSFUL - WILL TRY AGAIN PRIOR
TO CUTTING ROAD.*

Permit Issued: Date 2/19/91

By:

Dennis P. Roy

Application Denied: Date

By:

Work Inspected and Approved: Date

10/10/95

By:

Dennis P. Roy

(over)

INDEXED

TOWN OF ACTON

INTER-DEPARTMENTAL COMMUNICATION

DATE: 2/7/91

TO: Don P. Johnson, Town Manager
FROM: Engineering Department
SUBJECT: STREET OPENING PERMIT
Pamet Systems, Inc.


As you know, Pamet Systems, Inc. has requested permission to install a new gas service at 1000 Main Street. Since the "open season" on street cuts is not until March 15th, permission must be granted by the Board of Selectmen to allow the installation. Pamet has made a written request to the Board citing financial hardship as a reason for the early installation date. The gas company has already made an application to do the work and we have put them on hold pending approval by the Board of Selectmen.

Our major concerns with this installation are the high volume of traffic on Main Street and the potential for frost. With this in mind, we would request that the Selectmen impose the following restrictions on the permit:

1. A uniformed police detail officer must be present at all times during construction to direct traffic. The cost of this officer shall be paid by Pamet Systems, Inc. or Boston Gas.
2. Prior to excavating the entire width of Main Street, the gas company must attempt to bore horizontally under the road to avoid an unnecessary patch.
3. All trenches and excavations must be backfilled and mechanically compacted in accordance with the Town's specifications for regulating construction within public ways. The backfill shall consist of the excavated material except that frozen or otherwise unsuitable material shall not be used as backfill. In any case, the top 18" of backfill shall consist of processed gravel as approved by the Acton Engineering Department.
4. A temporary hot top patch equal to the full depth of pavement on Main Street must be installed immediately upon the completion of the work and shall be maintained in accordance with the specifications for regulating construction within public ways. In this instance, due to the volume of traffic on Main Street, the permanent patch shall be treated with an infrared heater.
5. Since the adoption of the revised specifications, a fee of \$50.00 will be required for this permit.

6. This Department must be notified 24 hours before the start of construction so that inspections can be scheduled.

We have discussed these conditions with the gas company and they have agreed to abide by them. The Board should reserve time at an upcoming meeting to vote on this request. If you have any questions or need additional information, please let us know.


Dennis P. Ring
Engineering Assistant II

DPR/dmj

Pamet Systems, Inc.

Police And Municipal Emerging Technologies

January 29, 1991

Board of Selectmen
Town of Acton
472 Main St.
Acton, Massachusetts 01720

Gentlemen:

Pamet Systems has recently purchased the building at 1000 Main St. The facility is partially completed and has been unoccupied for the past 18 months. Pamet Systems has recently become a public company and will be expanding from our current site at 989 Main St.

Pamet Systems is requesting permission to install a gas line to the building so that we may accelerate our scheduled occupancy date while avoiding the cost of temporary gas storage facilities and the refitting of some 11 burner units. A delay in the occupancy date will cause us both operational and financial hardship as the company is experiencing significant growth in the Acton community.


The installation of the line will require that the road be cut. The company will comply with any conditions or restrictions that the Board sees fit to apply.

Thank you for considering this application and we look forward to your positive response. We will be pleased to provide any additional information that may be needed.

Sincerely,



Richard C. Becker
Vice President



COPYRIGHT BY THE BOSTONGAS COMPANY

ACT

