

Date 8/2/01

Permit No. 01-43

TOWN OF ACTON

APPLICATION FOR PERMIT TO CONSTRUCT WITHIN A PUBLIC WAY

This application must be submitted not less than five (5) days prior to any Construction within a public way.

Notice 24 hours in advance of any construction must be given to the Town Engineer.

- 1. Permittee: Bentley Building Address: 503 mandinglake RD. NH
- 1A. Telephone #: 603.885.0700
- 2. Location of Proposed Construction: 127 Summer St
- 3. Purpose of Construction: New House
- 4. Length of Cut:
- 5. Width of Cut: 11' wide Just to make sure
- 6. Width of Existing Pavement: that is all the way across
- 7. Type of Existing Roadway Surface: pave Type of Curb: N/A
- 8. Type of Existing Sidewalk Surface: N/A Type of Shoulder: grass
- 9. Date of Street Opening: From To
- 10. For Work Involving Excavations: Dig Safe Number 201 310 72163

I, the undersigned, hereby declare that I have read and agree to the Town of Acton Specifications for Regulating Construction with Public Ways dated January 8, 1991. I have deposited the required bond with the Town of Acton, and I covenant and agree that the Town may deduct from this amount the cost of repairs to the road surface, curbs, shoulders, walls or other features within the right-of-way including replacing bounds if not completed by me to the satisfaction of the Town Engineer within the specified time.

Special Instructions:

Signature of Applicant

\$25 filing fee

\$500 bond

no road bounds

Summer St was paved 1998

Permit Issued: Date 8/2/01

By: C. D. J.

Application Denied: Date


By:

Work Inspected and Approved: Date 7/29/2002


By: C. D. J.

SKETCH

SECTION A-A



NOTE: 1. FINAL PATCH DEPTH
2. SEE SPECIFICATIONS FOR
3. OIL TREATED ROADS
4. BIT. CONC. ROADS
5. FURTHER REQUIREMENTS



TOWN OF ACTON
TRENCH DETAIL
FEB. 1969
NO SCALE

Town of Acton
Permit to Construct Within a Public Way
(Release)

To: Town Treasurer

Date: 7/29/02

From: Engineering Department

Subject: Performance Deposit - Permit to Construct Within a Public Way #: 2001-043

Please release the enclosed performance deposit in the form of:

Certified Check #: _____ Bank: _____

Personal Check #: 19271 Bank: Bank of New Hampshire

Other (specify): _____

In the amount of \$ 500.00, to (Permitee) Bentley Building Corp

which is being held as security for Permit to Construct Within a Public Way #: 2001-043

located at (address) 127 Summer Street

For authority, see section 3.1 of the Town of Acton Specifications for Regulating Construction Within Public Ways. The work proposed under this permit has been satisfactorily completed.

Account #: 81 25300

Amount: \$ 500.00

Mailing Address of Permitee:

Bentley Building Corp.

503 Main Dunstable Road

Nashua, New Hampshire 03062

Signed: 
Acton Engineering Department

Town of Acton
Permit to Construct Within a Public Way
(Hold)

To: Town Treasurer

Date: 8/2/2001

From: Engineering Department

Subject: Performance Deposit - Permit to Construct Within a Public Way #: 2001-42 & 2001-43

Please hold the enclosed performance deposit in the form of:

Certified Check #: _____ Bank: _____

Personal Check #: 19271 Bank: Bank of New Hampshire

Other (specify): _____

In the amount of \$ 2000.00, from (Permitee) Bentley Building Corporation
as security for Permit to Construct Within a Public Way # 2001-42 & 2001-43

located at (address) 127 Summer Street


For authority, see section 3.1 of the Town of Acton Specifications for Regulating Construction Within Public Ways. This deposit is to be held until released in writing by this department.

Account #: 81 25300

Amount: \$ 2000.00

Mailing Address of Permitee:

Bentley Building Corporation
503 Main Dunstable Road
Nashua, New Hampshire 03062

Signed: 
Acton Engineering Department



TOWN OF ACTON
472 Main Street
Acton, Massachusetts, 01720
Telephone (978) 264-9628
Fax (978) 264-9630

Engineering Department

NOTICE OF INSPECTION

To: Bentley Building Corp.

Location: 127 Summer Street

Date: 2/12/2002

Subject: Permit to Construct within a Public Way #2001-043 (new driveway)

COMMENTS:

We will need to hold the \$500 performance bond until the following items are complete:

1. The road shoulder needs to be graded and stabilized with a 4-6 inch layer of loam and seed or some other acceptable alternative to prevent erosion.
2. The final course of paving for the driveway still needs to be completed. We noted that the driveway only has the binder course of pavement.

THE REQUIREMENTS FOR ANY WORK WITHIN A PUBLIC WAY ARE SET FORTH IN THE "TOWN OF ACTON SPECIFICATIONS FOR REGULATING CONSTRUCTION WITHIN PUBLIC WAYS". COPIES ARE AVAILABLE IN THE ENGINEERING DEPARTMENT.

D.A. 0.5 hr
C.Y. 0.5 hr
