



Water Supply District of Acton

693 MASSACHUSETTS AVENUE
P.O. BOX 953
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107

FAX (978) 264-0148

DATE: August 1, 2014

TO: Town of Acton Building Department

FROM: Chris Allen, District Manager

RE: Comments on 267 Great Road/SPSP #07-03-14-451

1. All water mains, services, appurtenances and installation of such must comply with Acton Water District (AWD) specifications.
2. Water main/service sizes are not annotated on the proposed plan. It is assumed fire suppression will be via a ≥ 6 " fire line.
3. The proposed development will require $>5,000$ Gallons-per-day (GPD), and/or the proposed connection to existing water infrastructure is >2 ", the owner, or owner's representative, must submit a "Water Impact Report" per Appendix 2 of AWD "Rules & Regulations". This report shall be submitted and approved prior to the commencement of water infrastructure installation. Additional comments on water efficiency and use reduction will be reserved until the Report is submitted.
4. A proposed "As-Built" plan of the water infrastructure must be submitted, reviewed and approved by AWD prior to any installation of said infrastructure.
5. A final "As-Built" plan denoting exact locations of all water infrastructure will be submitted by the contractor prior to filling of any water mains for pressure test or disinfection per AWD specifications.
6. Any existing source of water supply shall be removed from the site and/or adequately protected from creating a cross connection to the AWD water system.

Respectfully submitted

Chris Allen
District Manager
