

## Scott Mutch

---

**From:** Steven Ventresca [SVentresca@nitscheng.com]  
**Sent:** Monday, October 06, 2014 2:43 PM  
**To:** Scott Mutch  
**Subject:** Revised Cover and Layout Plan  
**Attachments:** 10079CLO-2014-10-06.pdf; 10079COVER-2014-10-06.pdf

Scott,

Here are the revised Cover Sheet and Layout Sheet as we discussed earlier today.

Cover Sheet:

The Open Space calculation was corrected so that the percentages refer to the amount of open space. The original submittal noted the percentage of impervious area.

Layout Sheet:

Relocated bicycle parking in front of the door and added three (3) spaces perpendicular to the bicycle aisle. Provided an additional Handicapped Parking Space per ADA with pavement marking and sign, revised bollard layout.

Let me know if you have any other comments or changes.

Steve

**Steven Ventresca, PE, LEED AP BD+C | Project Manager**

*25 years of building better communities with you*

Nitsch Engineering | 2 Center Plaza, Suite 430, Boston, MA 02108 | [www.nitscheng.com](http://www.nitscheng.com)  
Main: 617-338-0063 | Direct: 857-206-8714 | Fax: 617-338-6472 | [sventresca@nitscheng.com](mailto:sventresca@nitscheng.com)

WBE in MA, NY, PA, and VA; WBENC national certification

This E-mail message and its attachments (if any) are intended only for the designated recipient(s). In addition, this message and the attachments (if any) may contain information that is proprietary, confidential, or privileged and exempt from disclosure or otherwise protected under applicable law. If you are not the designated recipient of this message, you may not read, disclose, reproduce, distribute, disseminate or otherwise use this transmission. Delivery of this message to any person other than the intended recipient is not intended to waive any right or privilege. If you have received this message in error, please promptly notify the sender or Nitsch Engineering, Inc. by reply E-mail and immediately delete this message from your system.