



# Water Supply District of Acton

693 MASSACHUSETTS AVENUE  
P.O. BOX 953  
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107

FAX (978) 264-0148

DATE: 11/21/14

TO: Town of Acton Planning Department

FROM: Chris Allen, District Manager

RE: Comments on Hayward Farms Definitive Subdivision

1. The proposed development will require  $>2,500$  Gallons-per-day (GPD) and/or the extension of the water main is  $> 2'$ , the owner, or owner's representative, must submit a "Water Impact Report" per Acton Water District (AWD) Rules & Regulations. Additional comments on water efficiency and use reduction will be reserved until the Report is submitted. The report shall cover both the subdivision and ANR lots. This report shall; be submitted and accepted by the AWD prior to the commencement of water infrastructure installations.
2. Due to an existing service for the existing house, we recommend usage of this water service for Lot #1. If not re-used, it will be required to be shutoff and disconnected at the water main in the Public Right of Way. **NOTE:** This was upgraded to current specification during the recent Hayward Road water main improvement.
3. All water mains, services, appurtenances and installation of such must comply with AWD specifications. (Hard copy may be picked up at AWD main office)
4. A proposed "As-Built" plan of the water infrastructure must be submitted, reviewed and approved by AWD prior to any installation of said infrastructure. Preferably, this plan will depict only the existing and proposed water infrastructure.
5. A final "As-Built" plan denoting exact locations of all water infrastructure will be submitted by the contractor prior to filling of any water mains for pressure test or disinfection per AWD specifications.

Respectfully submitted

Chris Allen  
District Manager