

Kim Gorman

From: Robert Hart
Sent: Friday, February 27, 2015 12:17 PM
To: Kim Gorman; Assessor Department; Building Department; Natural Resources Department; Engineering Department; Health Department; Municipal Properties Department; Police Department; Fire Department; Historical Commission; Historic District Commission; Sidewalk Committee; Chris Allen
Cc: Planning Department; Police Department
Subject: RE: Review of an application for approval of Definitive Plan - 456 Massachusetts Avenue - Comments

Hello Kim,

The Fire Department will be requiring a hydrant near the turn around on this common drive. Also the name is fairly close to Jay lane and may cause confusion for emergency responders. This will need to be looked at more closely. The width of the final pavement I could not see on the plans provided. Other than that we will address issues as the project moves along.

Respectfully,

Robert Hart
Deputy Fire Chief

From: Kim Gorman
Sent: Wednesday, February 11, 2015 9:16 PM
To: Assessor Department; Building Department; Natural Resources Department; Engineering Department; Health Department; Municipal Properties Department; Police Department; Fire Department; Historical Commission; Historic District Commission; Sidewalk Committee; Chris Allen
Cc: Planning Department; Police Department
Subject: Review of an application for approval of Definitive Plan - 456 Massachusetts Avenue - Comments
Importance: High

Hello,

We are in receipt of an application for approval of an application for approval of the Definitive Plan for 456 Massachusetts Avenue.

Below is the link to view the documents within docushare -

<http://doc.acton-ma.gov/dsweb/View/Collection-6569>

Please forward your comments to the Planning Department no later than **Friday, February 27, 2015**. I have attached a memo document, if needed.

If you would like to view a set of the paper application, please let me know.

Please don't hesitate to contact me if you have any questions or concerns.

Thank you!

Sincerely,
Kim Gorman
Acton Planning Dept.
978-929-6631