TOWN OF ACTON
Health Department
472 Main Street
Acton, Massachusetts, 01720
Telephone (978) 929-6632
Fax (978) 929-6340

June 29, 2015

To: Planning Department
From: Health Department
Re: Site Plan Special Permit #SPSP 05/29/15-454 for 87 Hayward Road

1. Any septic system being paved over must be approved for H-20 loading and vented.
2. HAARTZ will need to inquire with Sheryl Ball at the Acton Health Department about putting in a cafeteria. A food service permit may be required.
3. Approved new septic system must be able to accommodate any additional flow from cafeteria uses.