

From: Robert Hart

Sent: Thursday, November 12, 2015 2:15 PM

To: Kim Gorman; Building Department; Planning Department; Engineering Department; Patrick Futterer; Health Department; Natural Resources Department; Sidewalk Committee; Chris Allen; Design Review Board; Economic Development Committee; Transportation Advisory Committee

Cc: Lisa Tomyl

Subject: RE: 267 Great Road - Site Plan Special Permit Application - Comments

Hello Kim,

Minimum inside turning radius is 25 Feet, the drive must be 20 feet wide to meet current access code (527 CMR 1.0) Fire apparatus access road plans must include an analysis and evaluation of fire apparatus maneuvers throughout the access roads created by swept path analysis and turn simulation software, per 527 CMR 18.0.

Respectfully,

Robert Hart
Deputy Fire Chief
Acton Fire Department

From: Kim Gorman

Sent: Thursday, November 12, 2015 10:36 AM

To: Building Department; Planning Department; Engineering Department; Patrick Futterer; Robert Hart; Health Department; Natural Resources Department; Sidewalk Committee; Chris Allen; Design Review Board; Economic Development Committee; Transportation Advisory Committee

Cc: Lisa Tomyl

Subject: 267 Great Road - Site Plan Special Permit Application - Comments

Importance: High

Good afternoon,

I am in receipt of an application for a Site Plan Special Permit #SPSP 11/06/15 - 458 for 267 Great Road.

The location of the documents are within docushare, here is the link - <http://doc.acton-ma.gov/dsweb/View/Collection-7091>

The applicant is proposing development of four (4) single family dwellings with associated private drive.

Please email your questions or comments if any to the Planning Department – planning@acton-ma.gov no later than Friday, December 11, 2015.

Thank you!

Sincerely,
Kim Gorman
Secretary
Acton Planning Department
472 Main Street
Acton, MA 01720
kgorman@acton-ma.gov
978-929-6631