



Water Supply District of Acton

693 MASSACHUSETTS AVENUE
P.O. BOX 953
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107

FAX (978) 264-0148

DATE: 1/8/2016

TO: Town of Acton Planning Department

FROM: Chris Allen, District Manager

RE: Comments on 180-182 Skyline Drive/SP #11/20/15-459

1. If the proposed development will require >2,500 Gallons-per-day (GPD), or the new connection to the existing piping system is > 2", the owner, or owner's representative, must submit a "Water Impact Report" per Acton Water District (AWD) guidelines. Additional comments on water efficiency and use reduction will be reserved until the Report is submitted.
2. All water mains, services, appurtenances and installation of such must comply with AWD specifications. (Hard copy may be picked up at AWD main office)
3. A proposed "As-Built" plan of the water infrastructure must be submitted, reviewed and approved by AWD prior to any installation of said infrastructure.
4. A final "As-Built" plan denoting exact locations of all water infrastructure will be submitted by the contractor prior to filling of any water mains for pressure test or disinfection per AWD specifications.
5. Except for an emergency supply of water to interconnected municipal water systems, notwithstanding any existing or future water service connection, no water service shall be provided for the use of any city, town or municipality, except for the Town of Acton, without a vote of the Commissioners and after a finding that such provision of water is beneficial to the District and in the best interest of the District and the Town of Acton. *

*- Excerpt from AWD "Rules & Regulations" applicable to this project.

Respectfully submitted

Chris Allen
District Manager