

BOARD OF HEALTH

Please ensure that any additions of the foundation remain at least 10 feet away from the septic system. Additionally, sonotube footings must also remain 10 feet away from septic system components, with the exception that a footing may be as close as 5 feet to a septic tank or pump chamber as long as the footing reaches a depth in the ground equivalent to the bottom of the tanks.