



Town of Acton
Department of Public Health
 472 Main Street, Acton, MA 01720
 Phone: (978) 929-6632 Fax: (978) 929-6340
 www.acton-ma.gov

ANNUAL INSPECTION HAZARDOUS MATERIALS PERMIT HOLDER

Facility Name: Colonial Acres WWTF Date 9/5/2013
 Address: 1 Squirrel Hill Road
 Type of Business: Waste water treatment facility
 Telephone: 978-815-9259 Email: Vurgaropulos@wseinc.com
 Contact Person: Jim Vurgaropulos Initial Inspection Re-Inspection

Housekeeping:	Y	N	Comments
Area clean		X	Please clean up shed a bit, especially the nitrate testing tubes containing sulfuric acid. Please handle with caution
Spills present	X		
Appropriate material storage	✓		
Materials and wastes separate	✓		No waste
Cleanup materials available		X	Observed broom and a few absorbent pads but no haz waste bucket
Materials have secondary containment	✓		
Materials and wastes are labeled	✓		
Safety:			
Are MSDS sheets available on site		X	No MSDS sheets visible on first inspection
Employee personal protective equipment on site		X	No PPE observed
Employees trained in Haz Mat handling	✓		
Emergency procedures posted	✓		Please update Acton BOH phone # 978-929-6632
Site Management:			
Waste removed by licensed hauler	✓		No waste
Floor drains present in area of Haz Mat or waste		✓	
Sinks present in area of Haz Mat or waste	✓		Above area of hazardous material
Testing of septic system necessary		✓	
Does site plan on file reflect current arrangement	✓		
Any UST (underground storage tank) present		✓	
If UST present, is it alarmed		✓	

Action Items:

1. Clean/organize shed
2. Please provide waste clean up bucket *Waste taken to truck*
3. Please provide copies of MSDS sheets on site
4. handled *In truck*
5. new Acton BOH phone number
6. chemical

Re-inspection required? Yes No
 Inspector Signature [Signature] Date _____

MSDS on top shelf

Re-inspection Date: Will schedule with Jim.
 No representative on site. Email copy to Jim
 Facility Representative Signature [Signature] Date 9/5/2013