
INTEROFFICE MEMORANDUM

TO: KIM DELNIGRO, PLANNING AND ENGINEERING SECRETARY
FROM: ROBERT C. CRAIG, FIRE CHIEF
SUBJECT: ELLSWORTH VILLAGE – SENIOR PLAN REVISIONS
DATE: 4/11/05
CC:

Kim,

Please be advised that I have reviewed the above named plan revising the previous items that we mentioned have been addressed. The only comment that I would make is that the emergency access would be considered a fire lane and under state regulations must be a minimum of eighteen (18) feet in width with the same width gate and would have to have designated signage.



Robert C. Craig

Fire Chief