

EXTRA INFO 7/18/05 - (8)

TOWN OF ACTON
472 Main Street
Acton, Massachusetts, 01720
Telephone (978) 264-9612
Fax (978) 264-9630

The Board of Selectmen hereby move to approve the order of location for utility pole (31/53) located on the southwesterly side of Main Street approximately 45 feet from the southwest side of Nylander Way. Subject to the following special conditions:

Special Conditions for Utility Pole #31/53 – 136 Main Street, Acton, MA

Cables to be attached to the new utility pole 31/53 are as follows:

- Top of pole is primary cable
- 20-inches below is secondary cable
- 24-inches below is the fire alarm cable
- 10-inches below is cable TV
- 20-inches below is telephone

The new utility pole will be:

- 45 feet high with 6 feet in the ground
- Made of hard pine (penta)
- Pressure treated through injection (not to be treated by NStar)
- No guy wires allowed
- On top of the pole will be 336 open wire primary cable – 20" below will be the 3x1/0 secondary cable

Date Moved & Approved: _____

Peter K. Ashton, Chairman

Walter M. Foster, Vice Chairman

Robert A. Johnson, Clerk

F. Dore Hunter, Member

Lauren Rosenzweig, Member

BOARD OF SELECTMEN

ORDER FOR JOINT OR IDENTICAL LOCATIONS FOR POLES
Town of **ACTON**, Massachusetts

WHEREAS, **BOSTON EDISON COMPANY** and **VERIZON NEW ENGLAND, INC.** have petitioned for joint or identical locations for the erection or construction of poles to be owned and used in common by them upon, along and across the public way or ways of the Town hereinafter specified, and notice has been given and a hearing held on said petition as provided by law.

It is **ORDERED** that **BOSTON EDISON COMPANY** and **VERIZON NEW ENGLAND, INC.** be and hereby are granted joint or identical locations for the erection or construction of poles, to be owned and used in common by them, and for such other fixtures including anchors and guys as may be necessary to sustain or protect the wires of the line upon, along and across the following public way or ways of said Town:

Main Street **Southwesterly side, approximately 45 feet southwest of Nylanders Way**
One (1) pole (31/53)

All construction work under this Order shall be in accordance with the following conditions:
Poles shall be of sound timber and located as shown on a plans made by **P. Dion** dated **April 11, 2005** on file with said petition. There may be attached to said poles by said **BOSTON EDISON COMPANY** and by said **VERIZON NEW ENGLAND, INC.** wires and cables necessary for the conduct of their business. All such wires and cables shall be placed at a height of not less than eighteen feet from the ground at crossings of other ways and at not less than fourteen feet from the ground elsewhere.
See list of additional special conditions attached.

Selectmen of
the Town of
ACTON

CERTIFICATE

We hereby certify that the foregoing Order was adopted after due notice and a public hearing as prescribed by Section 22 of Chapter 166 of the General Laws (Ter.Ed.), and any additions thereto or amendments thereof, to wit: -after written notice of the time and place of the hearing mailed at least seven days prior to the date of the hearing by the Selectmen to all owners of real estate abutting upon that part of the way or ways upon, along or across which the line is to be constructed under said Order, as determined by the last preceding assessment for taxation, and a public hearing held at _____ in said Town on _____ day of _____, 2005 at _____ P.M.

Selectmen of
the Town of
ACTON

CERTIFICATE

~~I hereby certify that the foregoing are true copies of the Order of the Board of Selectmen of the Town of **ACTON** Massachusetts, duly adopted on the _____ day of _____ 2005, and recorded with records of location Orders of said Town, Book _____, Page _____, and of the certificate of notice of hearing thereon required by Section 22 of Chapter 166 of the General Laws (Ter. Ed.), and any additions thereto or amendments thereof, as the same appear of record.~~

Attest: _____
Clerk of the Town of **ACTON**, Massachusetts

TOWN OF ACTON
472 Main Street
Acton, Massachusetts, 01720
Telephone (978) 264-9612
Fax (978) 264-9630

Special Conditions for Utility Pole #31/53 – 136 Main Street, Acton, MA

Cables to be attached to the new utility pole 31/53 are as follows:

- Top of pole is primary cable
- 20-inches below is secondary cable
- 24-inches below is the fire alarm cable
- 10-inches below is cable TV
- 20-inches below is telephone

The new utility pole will be:

- 45 feet high with 6 feet in the ground
- Made of hard pine (penta)
- Pressure treated through injection (not to be treated by NStar)
- No guy wires allowed
- On top of the pole will be 336 open wire primary cable – 20" below will be the 3x1/0 secondary cable