



Water Supply District of Acton

693 MASSACHUSETTS AVENUE
P.O. BOX 953
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107

FAX (978) 264-0148

DATE: 11/8/2010

TO: Town of Acton Building Department

FROM: Chris Allen, District Manager

RE: Comments on Beacon Court

1. All water mains, services, appurtenances and installation of such must comply with AWD specifications. (Hard copy may be picked up at AWD main office)
2. A proposed "As-Built" plan of the water infrastructure must be submitted, reviewed and approved by AWD prior to any installation of said infrastructure.
3. The owner/developer must make application for service at The Water District main office at 693 Massachusetts Ave, Acton, MA, prior to tapping any existing water mains.
4. Since the plans do not annotate a water supply line size, and there is a hydrant shown, it is assumed that the water main size is 6". Unless future expansion is possible, where the water main would be extended, The Water District recommends installation of a common 2" High Density Polyethylene (HDPE) line in lieu of a 6" line to prevent stagnant water from potentially degrading water quality due to high residence time.
5. A final "As-Built" plan denoting exact locations of all water infrastructure will be submitted by the contractor/developer prior to filling of any water mains for pressure test or disinfection, or setting of any water meters per AWD specifications.

Respectfully submitted

Chris Allen
District Manager