



TOWN OF ACTON
Health Department
472 Main Street
Acton, Massachusetts, 01720
Telephone (978) 929-6632
Fax (978) 929-6340

May 19, 2015

To: Board of Appeals
From: Evan Carloni, Health Department
Re: **Hearing #15-09 - Special Permit - 19 Henley Road**

.....

Please ensure that any additions of foundation remain at least 10 feet away from septic system. Additionally, sonotube footings must also remain 10 feet away from septic system components, with the exception that a footing may be as close as 5 feet to a septic tank or pump chamber as long as the footing reaches a depth in the ground equivalent to the bottom of the tank.