

From: [Frank Ramsbottom](#)
To: [Robert Hummel](#); [Building Department](#); [Natural Resources Department](#); [Health Department](#); [Fire Department](#); [Police Department](#); [Manager Department](#); [Design Review Board](#)
Cc: [Kimberly Bricker](#); [Planning Department](#)
Subject: RE: Munis link: Permit Application 2671 / 296 298 Central Street
Date: Wednesday, July 13, 2016 12:04:03 PM

The architectural plans are preliminary and lacking sufficient detail for a code review. A full building code review will be done upon application for the building permit.

Please keep in mind that the windows must meet the size requirements for ventilation and emergency egress/rescue.

Respectfully

Frank Ramsbottom
Building Commissioner
Town of Acton, MA
472 Main Street, 01720
Phone # 978-929-6633
Cell # 978-490-4199

From: Robert Hummel
Sent: Wednesday, July 13, 2016 8:19 AM
To: Building Department; Natural Resources Department; Health Department; Fire Department; Police Department; Manager Department; Design Review Board
Cc: Kimberly Bricker; Planning Department
Subject: RE: Munis link: Permit Application 2671

The applicant has submitted new plans for review and if there is any additional comments, please send them to planning@acton-ma.gov before next Wednesday - 7/20.

Please follow the link below to the revised plans
<http://doc.acton-ma.gov/dsweb/View/Collection-7965>

Thanks,
Robert Hummel
Assistant Town Planner
Town of Acton
978-929-6631

