



**TOWN OF ACTON**  
472 Main Street  
Acton, Massachusetts, 01720  
Telephone (978) 929-6633  
Fax (978) 929-6340

**Building Department**

---

August 15, 2013

Glenn Berger C/O  
Exchange Hall  
2 School Street  
Acton MA 01720

**Re: exchange Hall accessibility**

Dear Mr. Berger,

Per your request I am writing in order to update you the status of the accessibility of Exchange Hall. At this point the Hall and first floor are considered fully accessible. The elevator (LULA) has been inspected and approved by the state elevator examiners and I. The second floor is considered accessible pending the outcome of the bathroom variance. Your cabinet business in the basement floor is not accessible because it does not have the required parking space. If you choose not to repave you will need to modify your variance. With the Massachusetts Architectural Access Board to include the basement parking.

If you have any questions, please feel free to contact me at your convenience. PH 978-929-6633

Respectfully,

Mark Barbadoro  
Building Inspector