



Water Supply District of Acton

693 MASSACHUSETTS AVENUE
P.O. BOX 953
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107

FAX (978) 264-0148

DATE: 9/3/2013

TO: Town of Acton Planning Department

FROM: Chris Allen, District Manager

RE: Comments on the Residences at Constitution Drive

1. The proposed development will require >5,000 Gallons-per-day (GPD), and/or a connection to the existing water main >2", the owner, or owner's representative, must submit a "Water Impact Report" per Acton Water District (AWD) "*Rules & Regulations*".
2. All water mains, services, appurtenances and installation of such must comply with AWD specifications. (Hard copy may be picked up at AWD main office)
3. A proposed "As-Built" plan of the water infrastructure must be submitted, reviewed and approved by AWD prior to any installation of said infrastructure.
4. A final "As-Built" plan denoting exact locations of all water infrastructure will be submitted by the contractor in hard copy and .pdf format prior to filling of any water mains for pressure test or disinfection per AWD specifications.

Respectfully submitted

Chris Allen
District Manager