Water Supply District of Acton

693 MASSACHUSETTS AVENUE
P.O. BOX 953
ACTON, MASSACHUSETTS 01720

TELEPHONE (978) 263-9107 FAX (978) 264-0148

DATE: 2/27/2015

TO: Town of Acton Planning Department

FROM: Chris Allen, District Manager

RE: Comments on 456 Massachusetts Ave Definitive Subdivision

1. If the proposed development will require >2,500 Gallons-per-day (GPD), OR the connection to the existing water system is > 2", the owner, or owner's representative, must submit a "Water Impact Report" per Acton Water District (AWD) guidelines. Additional comments on water efficiency and use reduction will be reserved until the Report is submitted.

2. The supply line size is not specified on the site plan. Water lines >2" must be equipped with flush apparatus (fire hydrant for ≥ 6", or flush hydrant for smaller diameter lines)

3. Any new water service or fire line from the water main to a dwelling, building or structure will be in a separate, underground trench. No other utility will be in the same trench.

4. Any existing water service(s) to be abandoned must be abandoned in the Public Right of Way (PROW) at the existing water main.

5. All water mains, services, appurtenances and installation of such must comply with AWD specifications. Document available upon request.

6. A proposed "As-Built" plan of the water infrastructure must be submitted, reviewed and approved by AWD prior to any installation of said infrastructure.

7. A final "As-Built" plan denoting exact locations of all water infrastructure will be submitted by the contractor prior to filling of any water mains for pressure test or disinfection per AWD specifications.