

Notice of Intent

Under the Massachusetts Wetland Protection Act,

G.L. c. 131, s. 40

And

The Town of Acton Wetland Protection Bylaw

for

Duggan Road – Drainage Improvements

Acton, MA 01720

Date: July 21, 2014

Table of Contents

- Project Narrative
- Notice of Intent – WPA Form 3
- NOI Wetland Fee Transmittal Form
- Drainage Calculations
 - Existing Conditions
 - Proposed Conditions
 - Catchment Area Map
- Drainage Improvement Plans
 - Overall Drainage Improvement Plans
 - NOI Submittal Plan
- Certified Abutters List / Affidavit / Notice to Abutters

Attachments:

- A. USGS Map
- B. NHESP Estimated Habitats of Rare Wildlife & Priority Habitats of Rare Species, OLIVER:
MassGIS Mapping Tool
- C. Drainage Improvement Plans
- D. Photographs
 - a. Existing outlet at 28 Duggan Road
 - b. Flooding at 171/173 Willow Street

Project Narrative

Project Narrative

Duggan Road

Applicant/Project Name:

Project Name: Proposed Drainage Improvements – Duggan Road

Project Location: Duggan Road/Grist Mill Road

Applicant: Corey York, Town Engineer / Director of Public Works

472 Main Street, Acton, MA 01720

Telephone: (978) 929-6630

Fax: (978) 929-6340

Property Owner: Steve Ledoux, Town Manager

472 Main Street, Acton, MA 01720

Telephone: (978) 929-6630

Fax: (978) 929-6340

Representative: Paul Campbell, Assistant Town Engineer

472 Main Street, Acton, MA 01720

Telephone: (978) 929-6630

Fax: (978) 929-6340

Project Description

The existing drainage system in the neighborhood of Duggan Road and Grist Mill Road is aging and is in need of maintenance. The residents in the area have also commented that during moderate sized storms Duggan Road becomes flooded at the low point between 26 and 28 Duggan. The Town is proposing to replace the aging utilities, which are mostly corrugated

metal pipes, and replace them with properly sized utilities. The Engineering Department has inspected the drainage system in the neighborhood during rain storms. It was observed that a significant amount of stormwater bypasses the catch basins and flows downhill to the low point on Duggan Road.

In the past, to alleviate the flooding problem at the low point, the Highway Department constructed a drainage swale adjacent to the drainage easement on 26 Duggan Road. This swale alleviated the flooding problem at the low point but it is possible that this may have lead to additional flooding downstream between 171 and 173 Willow Street. Photos of this additional flooding have been provided with this report.

Existing Site Conditions

The existing drainage system is a composition of catch basins and manholes mostly connected by corrugated metal pipes. The pipes increase in size as it directs stormwater downstream to the low point on Duggan Road. The drainage system collects to a 15-inch corrugated metal pipe between 26 and 28 Duggan Road which outlets to a headwall behind 28 Duggan Road. Residents in the area have observed that this pipe outlets in the same manner as a fire hose during moderate sized storms, which is indicative of the pipe being undersized.

there is an intermittent stream at the headwall behind 28 Duggan Road and Bordering Vegetated Wetland (BVW) in the area of the headwall. The 100-foot Buffer Zone from the stream and BVW is about to the edge of Duggan Road.

Proposed Site Conditions

The existing drainage system will be excavated and replaced. The corrugated metal pipes will be replaced with precast concrete pipes that will be sized properly to handle a 25-year storm. Additional catch basins will be added along Grist Mill and in other areas. Curbing will be added or replaced along the roadway and the existing single catch basins will be replaced with double catch basins in order to direct more stormwater into the system and avoid having it collect at the low point. Calculations have been provided as part of this submittal.

In order to replace the 15-inch pipe between Duggan Road and the headwall, the area will need to be excavated which would require the removal of several trees and vegetation. This area is within the 50-foot buffer. The area will be restored back to existing conditions as practicable as possible.

Buffer Zone

The work within the Buffer Zone will include excavation of the headwall and 18-inch metal drainage pipe. The existing head wall will be reconstructed in kind.

The Town of Acton Wetland Bylaw prohibits certain activities within the Buffer Zone as well as other setback areas. The following outlines the prohibition and the projects respective compliance:

Wetland Protection Bylaw Section 3.3 and Chapter F 8.3 Wetland Setbacks for Existing Structures

0-foot setback for wetland-dependant structures (drain outfalls, weirs, etc), fences, and structures necessary for upland access where reasonable alternative access is unavailable.

Work associated with pre-existing structures or activities not presently in compliance with Section 3.2 may not increase the degree of “non-conformance” of those structures or activities.

This is an undersized drainage system that is also in need of repair. As it is a wetland-dependant structure, the required setback for new activities (Section 3.2) is 0-feet. The proposed project meets this new activity requirement.

Summary

The repair and replacement of the existing drainage system in the neighborhood of Duggan Road is a necessary procedure in the routine maintenance of the overall drainage system. The disturbance associated with this work is temporary in nature and all surfaces shall be restored post-construction. The proposed work is necessary to maintain a functioning stormwater system and maintaining public safety.

Notice of Intent – WPA Form 3



Massachusetts Department of Environmental Protection
 Bureau of Resource Protection - Wetlands
WPA Form 3 – Notice of Intent
 Massachusetts Wetlands Protection Act M.G.L. c. 131, §40


Provided by MassDEP:

MassDEP File Number

Document Transaction Number

City/Town

Important:
 When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



Note:
 Before completing this form consult your local Conservation Commission regarding any municipal bylaw or ordinance.

A. General Information

1. Project Location (**Note:** electronic filers will click on button to locate project site):

<u>Duggan Road</u>	<u>Acton</u>	<u>01720</u>
a. Street Address	b. City/Town	c. Zip Code
Latitude and Longitude:	<u>42d27'17"N</u>	<u>71d28'11"W</u>
<u>G1</u>	<u>287</u>	
f. Assessors Map/Plat Number	g. Parcel /Lot Number	e. Longitude

2. Applicant:

<u>Corey</u>	<u>York</u>	
a. First Name	b. Last Name	
<u>Town of Acton</u>		
c. Organization		
<u>472 Main Street</u>		
d. Street Address		
<u>Acton</u>	<u>MA</u>	<u>01720</u>
e. City/Town	f. State	g. Zip Code
<u>978-929-6630</u>	<u>978-929-6340</u>	<u>engineering@acton-ma.gov</u>
h. Phone Number	i. Fax Number	j. Email Address

3. Property owner (required if different from applicant): Check if more than one owner

<u>Steve</u>	<u>Ledoux</u>	
a. First Name	b. Last Name	
<u>Town of Acton</u>		
c. Organization		
<u>472 Main Street</u>		
d. Street Address		
<u>Acton</u>	<u>MA</u>	<u>01720</u>
e. City/Town	f. State	g. Zip Code
<u>978-929-6630</u>	<u>978-929-6340</u>	<u>engineering@acton-ma.gov</u>
h. Phone Number	i. Fax Number	j. Email address

4. Representative (if any):

<u>Paul</u>	<u>Campbell</u>	
a. First Name	b. Last Name	
<u>Town of Acton</u>		
c. Company		
<u>472 Main Street</u>		
d. Street Address		
<u>Acton</u>	<u>MA</u>	<u>01720</u>
e. City/Town	f. State	g. Zip Code
<u>978-929-6630</u>	<u>978-929-6340</u>	<u>engineering@acton-ma.gov</u>
h. Phone Number	i. Fax Number	j. Email address

5. Total WPA Fee Paid (from NOI Wetland Fee Transmittal Form):

<u>Town Project</u>	<u>\$0.00</u>	<u>\$0.00</u>
a. Total Fee Paid	b. State Fee Paid	c. City/Town Fee Paid



WPA Form 3 – Notice of Intent

Massachusetts Wetlands Protection Act M.G.L. c. 131, §40

Provided by MassDEP:

MassDEP File Number

Document Transaction Number

City/Town

A. General Information (continued)

6. General Project Description:

Drainage Improvements

7a. Project Type Checklist:

- | | |
|---|---|
| 1. <input type="checkbox"/> Single Family Home | 2. <input type="checkbox"/> Residential Subdivision |
| 3. <input type="checkbox"/> Limited Project Driveway Crossing | 4. <input type="checkbox"/> Commercial/Industrial |
| 5. <input type="checkbox"/> Dock/Pier | 6. <input checked="" type="checkbox"/> Utilities |
| 7. <input type="checkbox"/> Coastal Engineering Structure | 8. <input type="checkbox"/> Agriculture (e.g., cranberries, forestry) |
| 9. <input type="checkbox"/> Transportation | 10. <input type="checkbox"/> Other |

7b. Is any portion of the proposed activity eligible to be treated as a limited project subject to 310 CMR 10.24 (coastal) or 310 CMR 10.53 (inland)?

1. Yes No If yes, describe which limited project applies to this project:

2. Limited Project

8. Property recorded at the Registry of Deeds for:

a. County

b. Certificate # (if registered land)

c. Book

d. Page Number

B. Buffer Zone & Resource Area Impacts (temporary & permanent)

- Buffer Zone Only – Check if the project is located only in the Buffer Zone of a Bordering Vegetated Wetland, Inland Bank, or Coastal Resource Area.
- Inland Resource Areas (see 310 CMR 10.54-10.58; if not applicable, go to Section B.3, Coastal Resource Areas).

Check all that apply below. Attach narrative and any supporting documentation describing how the project will meet all performance standards for each of the resource areas altered, including standards requiring consideration of alternative project design or location.

For all projects affecting other Resource Areas, please attach a narrative explaining how the resource area was delineated.

<u>Resource Area</u>	<u>Size of Proposed Alteration</u>	<u>Proposed Replacement (if any)</u>
a. <input type="checkbox"/> Bank	1. linear feet	2. linear feet
b. <input checked="" type="checkbox"/> Bordering Vegetated Wetland	1. square feet	2. square feet
c. <input type="checkbox"/> Land Under Waterbodies and Waterways	1. square feet 3. cubic yards dredged	2. square feet



WPA Form 3 - Notice of Intent

Massachusetts Wetlands Protection Act M.G.L. c. 131, §40

Provided by MassDEP:
MassDEP File Number
Document Transaction Number
City/Town

B. Buffer Zone & Resource Area Impacts (temporary & permanent) (cont'd)

Resource Area, Size of Proposed Alteration, Proposed Replacement (if any)
d. Bordering Land Subject to Flooding
e. Isolated Land Subject to Flooding
f. Riverfront Area
2. Width of Riverfront Area (check one):
3. Total area of Riverfront Area on the site of the proposed project:
4. Proposed alteration of the Riverfront Area:
5. Has an alternatives analysis been done and is it attached to this NOI?
6. Was the lot where the activity is proposed created prior to August 1, 1996?
3. Coastal Resource Areas: (See 310 CMR 10.25-10.35)

Check all that apply below. Attach narrative and supporting documentation describing how the project will meet all performance standards for each of the resource areas altered, including standards requiring consideration of alternative project design or location.

Online Users: Include your document transaction number (provided on your receipt page) with all supplementary information you submit to the Department.

Resource Area, Size of Proposed Alteration, Proposed Replacement (if any)
a. Designated Port Areas
b. Land Under the Ocean
c. Barrier Beach
d. Coastal Beaches
e. Coastal Dunes



WPA Form 3 – Notice of Intent

Massachusetts Wetlands Protection Act M.G.L. c. 131, §40

Provided by MassDEP:

MassDEP File Number

Document Transaction Number

City/Town

B. Buffer Zone & Resource Area Impacts (temporary & permanent) (cont'd)

	<u>Size of Proposed Alteration</u>	<u>Proposed Replacement (if any)</u>
f. <input type="checkbox"/> Coastal Banks	_____	
	1. linear feet	
g. <input type="checkbox"/> Rocky Intertidal Shores	_____	
	1. square feet	
h. <input type="checkbox"/> Salt Marshes	_____	_____
	1. square feet	2. sq ft restoration, rehab., creation
i. <input type="checkbox"/> Land Under Salt Ponds	_____	
	1. square feet	

	2. cubic yards dredged	
j. <input type="checkbox"/> Land Containing Shellfish	_____	
	1. square feet	
k. <input type="checkbox"/> Fish Runs	Indicate size under Coastal Banks, inland Bank, Land Under the Ocean, and/or inland Land Under Waterbodies and Waterways, above	

	1. cubic yards dredged	
l. <input type="checkbox"/> Land Subject to Coastal Storm Flowage	_____	
	1. square feet	
4. <input type="checkbox"/> Restoration/Enhancement	If the project is for the purpose of restoring or enhancing a wetland resource area in addition to the square footage that has been entered in Section B.2.b or B.3.h above, please enter the additional amount here.	
	_____	_____
	a. square feet of BVW	b. square feet of Salt Marsh
5. <input type="checkbox"/> Project Involves Stream Crossings		
	_____	_____
	a. number of new stream crossings	b. number of replacement stream crossings

C. Other Applicable Standards and Requirements

Streamlined Massachusetts Endangered Species Act/Wetlands Protection Act Review

1. Is any portion of the proposed project located in **Estimated Habitat of Rare Wildlife** as indicated on the most recent Estimated Habitat Map of State-Listed Rare Wetland Wildlife published by the Natural Heritage and Endangered Species Program (NHESP)? To view habitat maps, see the *Massachusetts Natural Heritage Atlas* or go to http://www.mass.gov/dfwele/dfw/nhosp/regulatory_review/priority_habitat/online_viewer.htm.

a. Yes No **If yes, include proof of mailing or hand delivery of NOI to:**

**Natural Heritage and Endangered Species Program
Division of Fisheries and Wildlife
100 Hartwell Street, Suite 230
West Boylston, MA 01583**

Oct 1, 2008
b. Date of map



Provided by MassDEP:

MassDEP File Number

Document Transaction Number

City/Town

C. Other Applicable Standards and Requirements (cont'd)

If yes, the project is also subject to Massachusetts Endangered Species Act (MESA) review (321 CMR 10.18). To qualify for a streamlined, 30-day, MESA/Wetlands Protection Act review, please complete Section C.1.C, and include requested materials with this Notice of Intent (NOI); *OR* complete Section C.1.d, if applicable. *If MESA supplemental information is not included with the NOI, by completing Section 1 of this form, the NHESP will require a separate MESA filing which may take up to 90 days to review (unless noted exceptions in Section 2 apply, see below).*

1. c. Submit Supplemental Information for Endangered Species Review*

- 1. Percentage/acreage of property to be altered:
 - (a) within wetland Resource Area _____ percentage/acreage
 - (b) outside Resource Area _____ percentage/acreage
- 2. Assessor's Map or right-of-way plan of site
- 3. Project plans for entire project site, including wetland resource areas and areas outside of wetlands jurisdiction, showing existing and proposed conditions, existing and proposed tree/vegetation clearing line, and clearly demarcated limits of work ***
 - (a) Project description (including description of impacts outside of wetland resource area & buffer zone)
 - (b) Photographs representative of the site
 - (c) MESA filing fee (fee information available at: http://www.mass.gov/dfwele/dfw/nhesp/regulatory_review/ mesa/ mesa_fee_schedule.htm).
 Make check payable to "Commonwealth of Massachusetts - NHESP" and **mail to NHESP** at above address

Projects altering 10 or more acres of land, also submit:
 - (d) Vegetation cover type map of site
 - (e) Project plans showing Priority & Estimated Habitat boundaries

d. OR Check One of the Following

- 1. Project is exempt from MESA review.
 Attach applicant letter indicating which MESA exemption applies. (See 321 CMR 10.14, http://www.mass.gov/dfwele/dfw/nhesp/regulatory_review/ mesa/ mesa_exemptions.htm; the NOI must still be sent to NHESP if the project is within estimated habitat pursuant to 310 CMR 10.37 and 10.59.)
- 2. Separate MESA review ongoing. _____ a. NHESP Tracking # _____ b. Date submitted to NHESP

* Some projects **not** in Estimated Habitat may be located in Priority Habitat, and require NHESP review (see <http://www.mass.gov/dfwele/dfw/nhesp/nhesp.htm>, regulatory review tab). Priority Habitat includes habitat for state-listed plants and strictly upland species not protected by the Wetlands Protection Act.

** MESA projects may not be segmented (321 CMR 10.16). The applicant must disclose full development plans even if such plans are not required as part of the Notice of Intent process.



WPA Form 3 – Notice of Intent

Massachusetts Wetlands Protection Act M.G.L. c. 131, §40

Provided by MassDEP:

MassDEP File Number

Document Transaction Number

City/Town

C. Other Applicable Standards and Requirements (cont'd)

3. Separate MESA review completed.
Include copy of NHESP "no Take" determination or valid Conservation & Management Permit with approved plan.

2. For coastal projects only, is any portion of the proposed project located below the mean high water line or in a fish run?

a. Not applicable – project is in inland resource area only

b. Yes No

If yes, include proof of mailing or hand delivery of NOI to either:

South Shore - Cohasset to Rhode Island, and the Cape & Islands:

North Shore - Hull to New Hampshire:

Division of Marine Fisheries -
Southeast Marine Fisheries Station
Attn: Environmental Reviewer
1213 Purchase Street – 3rd Floor
New Bedford, MA 02740-6694

Division of Marine Fisheries -
North Shore Office
Attn: Environmental Reviewer
30 Emerson Avenue
Gloucester, MA 01930

Also if yes, the project may require a Chapter 91 license. For coastal towns in the Northeast Region, please contact MassDEP's Boston Office. For coastal towns in the Southeast Region, please contact MassDEP's Southeast Regional Office.

3. Is any portion of the proposed project within an Area of Critical Environmental Concern (ACEC)?

a. Yes No If yes, provide name of ACEC (see instructions to WPA Form 3 or MassDEP Website for ACEC locations). **Note:** electronic filers click on Website.

b. ACEC

4. Is any portion of the proposed project within an area designated as an Outstanding Resource Water (ORW) as designated in the Massachusetts Surface Water Quality Standards, 314 CMR 4.00?

a. Yes No

5. Is any portion of the site subject to a Wetlands Restriction Order under the Inland Wetlands Restriction Act (M.G.L. c. 131, § 40A) or the Coastal Wetlands Restriction Act (M.G.L. c. 130, § 105)?

a. Yes No

6. Is this project subject to provisions of the MassDEP Stormwater Management Standards?

a. Yes. Attach a copy of the Stormwater Report as required by the Stormwater Management Standards per 310 CMR 10.05(6)(k)-(q) and check if:

1. Applying for Low Impact Development (LID) site design credits (as described in Stormwater Management Handbook Vol. 2, Chapter 3)

2. A portion of the site constitutes redevelopment

3. Proprietary BMPs are included in the Stormwater Management System.

b. No. Check why the project is exempt:

1. Single-family house

Online Users:
Include your document transaction number (provided on your receipt page) with all supplementary information you submit to the Department.



WPA Form 3 – Notice of Intent

Massachusetts Wetlands Protection Act M.G.L. c. 131, §40

Provided by MassDEP:
MassDEP File Number
Document Transaction Number
City/Town

C. Other Applicable Standards and Requirements (cont'd)

- 2. Emergency road repair
- 3. Small Residential Subdivision (less than or equal to 4 single-family houses or less than or equal to 4 units in multi-family housing project) with no discharge to Critical Areas.

D. Additional Information

Applicants must include the following with this Notice of Intent (NOI). See instructions for details.

Online Users: Attach the document transaction number (provided on your receipt page) for any of the following information you submit to the Department.

- 1. USGS or other map of the area (along with a narrative description, if necessary) containing sufficient information for the Conservation Commission and the Department to locate the site. (Electronic filers may omit this item.)
- 2. Plans identifying the location of proposed activities (including activities proposed to serve as a Bordering Vegetated Wetland [BVW] replication area or other mitigating measure) relative to the boundaries of each affected resource area.
- 3. Identify the method for BVW and other resource area boundary delineations (MassDEP BVW Field Data Form(s), Determination of Applicability, Order of Resource Area Delineation, etc.), and attach documentation of the methodology.
- 4. List the titles and dates for all plans and other materials submitted with this NOI.

Duggan Road - Drainage System - Proposed Drainage

a. Plan Title

Town of Acton Engineering Department

b. Prepared By

12/17/2013

d. Final Revision Date

Paul Campbell, P.E.

c. Signed and Stamped by

1" = 10'

e. Scale

f. Additional Plan or Document Title

g. Date

- 5. If there is more than one property owner, please attach a list of these property owners not listed on this form.
- 6. Attach proof of mailing for Natural Heritage and Endangered Species Program, if needed.
- 7. Attach proof of mailing for Massachusetts Division of Marine Fisheries, if needed.
- 8. Attach NOI Wetland Fee Transmittal Form
- 9. Attach Stormwater Report, if needed.



WPA Form 3 – Notice of Intent

Massachusetts Wetlands Protection Act M.G.L. c. 131, §40

Provided by MassDEP:

MassDEP File Number

Document Transaction Number

City/Town

E. Fees

- Fee Exempt: No filing fee shall be assessed for projects of any city, town, county, or district of the Commonwealth, federally recognized Indian tribe housing authority, municipal housing authority, or the Massachusetts Bay Transportation Authority.

Applicants must submit the following information (in addition to pages 1 and 2 of the NOI Wetland Fee Transmittal Form) to confirm fee payment:

2. Municipal Check Number

3. Check date

4. State Check Number

5. Check date

6. Payor name on check: First Name

7. Payor name on check: Last Name

F. Signatures and Submittal Requirements

I hereby certify under the penalties of perjury that the foregoing Notice of Intent and accompanying plans, documents, and supporting data are true and complete to the best of my knowledge. I understand that the Conservation Commission will place notification of this Notice in a local newspaper at the expense of the applicant in accordance with the wetlands regulations, 310 CMR 10.05(5)(a).

I further certify under penalties of perjury that all abutters were notified of this application, pursuant to the requirements of M.G.L. c. 131, § 40. Notice must be made by Certificate of Mailing or in writing by hand delivery or certified mail (return receipt requested) to all abutters within 100 feet of the property line of the project location.

1. Signature of Applicant

2. Date

3. Signature of Property Owner (if different)

4. Date

5. Signature of Representative (if any)

6. Date

For Conservation Commission:

Two copies of the completed Notice of Intent (Form 3), including supporting plans and documents, two copies of the NOI Wetland Fee Transmittal Form, and the city/town fee payment, to the Conservation Commission by certified mail or hand delivery.

For MassDEP:

One copy of the completed Notice of Intent (Form 3), including supporting plans and documents, one copy of the NOI Wetland Fee Transmittal Form, and a **copy** of the state fee payment to the MassDEP Regional Office (see Instructions) by certified mail or hand delivery.

Other:

If the applicant has checked the "yes" box in any part of Section C, Item 3, above, refer to that section and the Instructions for additional submittal requirements.

The original and copies must be sent simultaneously. Failure by the applicant to send copies in a timely manner may result in dismissal of the Notice of Intent.

NOI Wetland Fee Transmittal Form



Massachusetts Department of Environmental Protection
 Bureau of Resource Protection - Wetlands
NOI Wetland Fee Transmittal Form
 Massachusetts Wetlands Protection Act M.G.L. c. 131, §40

Important: When filling out forms on the computer, use only the tab key to move your cursor - do not use the return key.



A. Applicant Information

1. Location of Project:

Duggan Road Acton, MA
 a. Street Address b. City/Town

 c. Check number d. Fee amount

2. Applicant Mailing Address:

Corey York
 a. First Name b. Last Name
Town of Acton
 c. Organization
472 Main Street
 d. Mailing Address
Acton MA 01720
 e. City/Town f. State g. Zip Code
978-929-6630 978-929-6430 engineering@acton-ma.gov
 h. Phone Number i. Fax Number j. Email Address

3. Property Owner (if different):

 a. First Name b. Last Name

 c. Organization

 d. Mailing Address

 e. City/Town f. State g. Zip Code

 h. Phone Number i. Fax Number j. Email Address

B. Fees

Fee should be calculated using the following process & worksheet. **Please see Instructions before filling out worksheet.**

Step 1/Type of Activity: Describe each type of activity that will occur in wetland resource area and buffer zone.

Step 2/Number of Activities: Identify the number of each type of activity.

Step 3/Individual Activity Fee: Identify each activity fee from the six project categories listed in the instructions.

Step 4/Subtotal Activity Fee: Multiply the number of activities (identified in Step 2) times the fee per category (identified in Step 3) to reach a subtotal fee amount. Note: If any of these activities are in a Riverfront Area in addition to another Resource Area or the Buffer Zone, the fee per activity should be multiplied by 1.5 and then added to the subtotal amount.

Step 5/Total Project Fee: Determine the total project fee by adding the subtotal amounts from Step 4.

Step 6/Fee Payments: To calculate the state share of the fee, divide the total fee in half and subtract \$12.50. To calculate the city/town share of the fee, divide the total fee in half and add \$12.50.

To calculate filing fees, refer to the category fee list and examples in the instructions for filling out WPA Form 3 (Notice of Intent).



Massachusetts Department of Environmental Protection
 Bureau of Resource Protection - Wetlands
NOI Wetland Fee Transmittal Form
 Massachusetts Wetlands Protection Act M.G.L. c. 131, §40

B. Fees (continued)

Step 1/Type of Activity	Step 2/Number of Activities	Step 3/Individual Activity Fee	Step 4/Subtotal Activity Fee

Step 5/Total Project Fee: _____

Step 6/Fee Payments:

Total Project Fee: _____
 a. Total Fee from Step 5

State share of filing Fee: _____
 b. 1/2 Total Fee **less** \$12.50

City/Town share of filing Fee: _____
 c. 1/2 Total Fee **plus** \$12.50

C. Submittal Requirements

- a.) Complete pages 1 and 2 and send with a check or money order for the state share of the fee, payable to the Commonwealth of Massachusetts.

Department of Environmental Protection
 Box 4062
 Boston, MA 02211

- b.) **To the Conservation Commission:** Send the Notice of Intent or Abbreviated Notice of Intent; a **copy** of this form; and the city/town fee payment.

To MassDEP Regional Office (see Instructions): Send a copy of the Notice of Intent or Abbreviated Notice of Intent; a **copy** of this form; and a **copy** of the state fee payment. (E-filers of Notices of Intent may submit these electronically.)

Drainage Calculations

- Existing Conditions
- Proposed Conditions
- Catchment Area Map

Storm Drainage Computations

Name: Duggan Road

Proj. No.:

Design Parameters:

Location: Acton, MA

Date:

1/6/2014

25 Year Storm*

Computed by:

PVC

n = VARIED

Checked by:

PVC

RUNOFF													DESIGN												
LOCATION		AREA (AC.)	C	C x A	SUM C x A	FLOW TIME (MIN)		i	Q _{cb} cfs	DCB? (Y/N)	Q _{ACTUAL} cfs	V _{ACTUAL} ft/s	PIPE DESIGN			CAPACITY			PROFILE						
FROM (upstream)	TO (downstream)					PIPE	CONC TIME						PIPE TYPE	PIPE SIZE	SLOPE (ft/ft)	Q full cfs	Q excess	V full ft/s	LENGTH	FALL	RIM UPPER	INV UPPER	INV LOWER	cover depth	
EX CB23	EX CB22	0.33	0.68	0.23	0.23	0.00	5.00	5.3	1.2	N	1.2	4.4	RCP	12	0.012	3.9	2.7	5.0	22.0	0.27	178.59	174.59	174.32	3.00	
EX CB22	EX CB16	0.12	0.95	0.11	0.34	0.00	5.00	5.3	0.58	N	1.8	8.0	RCP	12	0.047	7.7	5.9	9.8	393.9	18.50	178.57	174.07	155.57	3.50	
EX CB16	EX DMH4	0.11	0.95	0.10	1.10	0.00	5.00	5.3	0.55	N	5.8	10.4	RCP	12	0.043	7.4	1.6	9.4	36.7	1.59	160.27	155.57	153.98	3.70	
EX DMH4	DMH3				3.86	0.00	5.00	5.3			20.5	13.6	RCP	18	0.040	21.1	0.6	11.9	172.4	6.93	159.08	153.93	147.00	3.65	
DMH3	EX DMH3				4.33	0.00	5.00	5.3			23.0	14.9	RCP	18	0.048	23.1	0.1	13.1	103.6	5.00	152.00	147.00	142.00	3.50	
EX DMH3	EX DMH2				4.78	0.00	5.00	5.3			25.3	16.9	RCP	18	0.062	26.2	0.9	14.8	33.9	2.11	146.58	142.00	139.89	3.08	
EX DMH2	EX DMH1				7.52	0.00	5.00	5.3			39.9	25.9	RCP	18	0.143	39.8	-0.1	22.5	210.0	30.09	144.74	139.89	109.80	3.35	
EX DMH1	DMH2				7.98	0.00	5.00	5.3			42.3	15.7	RCP	24	0.036	43.2	0.9	13.7	46.6	1.70	117.28	109.80	108.10	5.48	
DMH2	DMH1				8.17	0.00	5.00	5.3			43.3	16.0	RCP	24	0.038	44.0	0.7	14.0	26.5	1.00	114.00	108.10	107.10	3.90	
DMH1	EX CB6				8.76	0.00	5.00	5.3			46.4	16.8	RCP	24	0.042	46.4	0.0	14.8	25.6	1.08	112.00	107.10	106.02		
EX CB6	EX CB5	0.11	0.95	0.11	8.86	0.00	5.00	5.3	0.57	N	47.0	17.8	RCP	24	0.047	49.0	2.0	15.6	249.4	11.69	110.82	106.02	94.33	2.80	
EX CB5	EX HD1	0.07	0.95	0.06	10.78	0.00	5.00	5.3	0.34	N	57.1	27.8	RCP	24	0.130	81.6	24.5	26.0	119.0	15.47	99.59	93.84	78.37	3.75	
EX CB21	EX CB20	1.00	0.47	0.47	0.47	0.00	5.00	5.3	2.47	Y	2.5	7.2	RCP	12	0.028	5.9	3.5	7.6	21.9	0.61	179.07	175.02	174.41	3.05	
EX CB20	EX CB18	0.74	0.53	0.39	2.56	0.00	5.00	5.3	2.09	Y	13.5	17.8	RCP	15	0.102	20.6	7.1	16.8	177.9	18.09	179.01	174.11	156.02	3.65	
EX CB18	EX DMH4	0.20	0.69	0.14	2.77	0.00	5.00	5.3	0.75	N	14.7	13.2	RCP	18	0.044	22.0	7.3	12.4	47.7	2.09	160.62	155.97	153.88	3.15	
EX CB15	EX CB14	2.02	0.55	1.11	1.11	0.00	5.00	5.3	5.88	Y	5.9	8.9	RCP	12	0.030	6.2	0.3	7.8	21.7	0.65	183.30	180.15	179.50	2.15	
EX CB14	EX CB12	1.42	0.58	0.83	1.94	0.00	5.00	5.3	4.38	Y	10.3	16.2	RCP	12	0.100	11.2	1.0	14.3	314.7	31.33	183.55	178.85	147.52	3.70	
EX CB12	EX DMH2	0.50	0.62	0.31	2.74	0.00	5.00	5.3	1.65	N	14.5	19.6	RCP	15	0.124	22.8	8.3	18.6	57.7	7.18	151.57	147.07	139.89	3.25	
EX CB2	EX CB4	0.12	0.95	0.12	0.12	0.00	5.00	5.3	0.61	N	0.6	4.7	RCP	12	0.026	5.7	5.1	7.3	39.3	1.01	99.46	96.26	95.25	2.20	
EX CB4	EX CB5	0.01	0.95	0.01	1.91	0.00	5.00	5.3	0.05	N	10.1	11.8	RCP	18	0.041	21.3	11.1	12.0	8.8	0.36	99.45	94.20	93.84	3.75	
EX CB1	EX CB3	2.26	0.51	1.16	1.16	0.00	5.00	5.3	6.15	Y	6.1	9.8	RCP	12	0.037	6.8	0.7	8.7	42.0	1.54	99.67	97.50	95.96	1.17	
EX CB3	EX CB4	1.14	0.55	0.63	1.79	0.00	5.00	5.3	3.32	Y	9.5	14.2	RCP	12	0.076	9.8	0.3	12.5	22.0	1.66	99.61	95.96	94.30	2.65	

Storm Drainage Computations

Name: Duggan Road

Proj. No.:

Design Parameters:

Location: Acton, MA

Date:

1/6/2014

25 Year Storm*

Computed by:

PVC

n = VARIED

Checked by:

PVC

RUNOFF													DESIGN											
LOCATION		AREA (AC.)	C	C x A	SUM C x A	FLOW TIME (MIN)		i	Q_cb cfs	DCB? (Y/N)	Q _{ACTUAL} cfs	V _{ACTUAL} ft/s	PIPE DESIGN			CAPACITY			PROFILE				cover depth	
FROM (upstream)	TO (downstream)					PIPE	CONC TIME						PIPE TYPE	PIPE SIZE	SLOPE (ft/ft)	Q full cfs	Q excess	V full ft/s	LENGTH	FALL	RIM UPPER	INV UPPER		INV LOWER
EX CB8	DMH2	0.36	0.51	0.18	0.18	0.00	5.00	5.3	0.98	N	1.0	6.0	RCP	12	0.034	6.5	5.6	8.3	27.3	0.92	114.07	110.92	110.00	2.15
EX CB7	DMH1	1.05	0.56	0.59	0.59	0.00	5.00	5.3	3.13	Y	3.1	5.6	RCP	12	0.012	4.0	0.9	5.1	16.0	0.20	110.84	107.40	107.20	2.44
EX CB13	EX CB12	0.95	0.52	0.49	0.49	0.00	5.00	5.3	2.61	Y	2.6	6.3	RCP	12	0.019	4.9	2.2	6.2	22.1	0.41	151.53	147.73	147.32	2.80
EX CB19	EX CB18	0.12	0.63	0.07	0.07	0.00	5.00	5.3	0.39	N	0.4	4.2	RCP	12	0.028	6.0	5.6	7.6	21.9	0.62	160.49	156.99	156.37	2.50
EX CB17	EX CB16	1.27	0.52	0.66	0.66	0.00	5.00	5.3	3.48	Y	3.5	5.6	RCP	12	0.012	3.9	0.4	4.9	22.0	0.26	160.23	156.08	155.82	3.15
EX CB10	EX DMH3	0.09	0.95	0.08	0.08	0.00	5.00	5.3	0.43	N	0.4	3.8	RCP	12	0.018	4.8	4.3	6.1	5.6	0.10	146.36	141.78	141.68	3.58
EX CB11	EX DMH3	0.72	0.51	0.37	0.37	0.00	5.00	5.3	1.95	N	1.9	5.3	RCP	12	0.014	4.3	2.3	5.4	16.1	0.23	146.61	141.81	141.58	3.80
EX CB9	EX DMH1	0.13	0.84	0.11	0.11	0.00	5.00	5.3	0.58	N	0.6	3.6	RCP	12	0.012	4.0	3.4	5.0	5.7	0.07	117.08	112.00	111.93	4.08
CB1	EX DMH1	0.53	0.65	0.35	0.35	0.00	5.00	5.3	1.85	N	1.8	9.0	RCP	12	0.065	9.0	7.2	11.5	15.5	1.00	117.08	113.50	112.50	2.58
CB2	DMH3	0.83	0.56	0.47	0.47	0.00	5.00	5.3	2.48	Y	2.5	3.7	RCP	12	0.005	2.5	0.0	3.2	14.0	0.07	151.88	148.88	148.81	2.00
DCB4	DCB3	0.87	0.69	0.60	0.60	0.00	5.00	5.3	3.17	Y	3.2	9.5	RCP	12	0.050	8.0	4.8	10.1	20.0	1.00	186.81	183.81	182.81	2.00
DCB3	DMH4	1.77	0.62	1.10	1.70	0.00	5.00	5.3	5.82	Y	9.0	10.8	RCP	15	0.036	12.2	3.2	10.0	175.6	6.29	187.04	182.81	176.52	2.98
DMH4	EX CB20				1.70	0.00	5.00	5.3			9.0	10.2	RCP	15	0.031	11.4	2.4	9.3	45.6	1.42	180.75	176.42	175.00	3.08

Storm Drainage Computations

Name: Duggan Road

Proj. No.:

Design Parameters:

Date: 1/6/2014

25 Year Storm*


Location: Acton, MA

Computed by: PVC

n = VARIED

Checked by: PVC

RUNOFF														DESIGN										cover depth
LOCATION		AREA (AC.)	C	C x A	SUM C x A	FLOW TIME (MIN)		i	Q _{cb} cfs	DCB? (Y/N)	Q _{ACTUAL} cfs	V _{ACTUAL} ft/s	PIPE DESIGN			CAPACITY			PROFILE					
FROM (upstream)	TO (downstream)					PIPE TIME	CONC TIME						PIPE TYPE	PIPE SIZE	SLOPE (ft/ft)	Q full cfs	Q excess	V full ft/s	LENGTH	FALL	RIM UPPER	INV UPPER	INV LOWER	
CB23	CB22	0.33	0.68	0.23	0.23	0.00	5.00	5.3	1.2	N	1.2	4.4	RCP	12	0.012	3.9	2.7	5.0	22.0	0.27	178.59	174.59	174.32	OK 3.00
CB22	CB16	0.12	0.95	0.11	0.34	0.00	5.00	5.3	0.58	N	1.8	8.0	RCP	12	0.047	7.7	5.9	9.8	393.9	18.50	178.57	174.07	155.57	OK 3.50
CB16	DMH4	0.11	0.95	0.10	0.44	0.00	5.00	5.3	0.55	N	2.3	8.3	RCP	12	0.043	7.4	5.1	9.4	36.7	1.59	160.27	155.57	153.98	OK 3.70
DMH4	DMH3				3.21	0.00	5.00	5.3		N	17.0	11.1	RCP	12	0.045	7.6	-9.4	9.7	276.0	12.50	159.08	153.93	141.43	PRC 4.15
DMH3	DMH2				4.13	0.00	5.00	5.3		N	21.9	11.1	RCP	12	0.045	7.6	-14.3	9.7	33.9	1.54	146.58	141.43	139.89	PRC 4.15
DMH2	DMH1				6.87	0.00	5.00	5.3		N	36.4	22.0	RCP	15	0.133	23.5	-12.9	19.2	210.0	27.86	144.74	139.89	112.03	PRC 3.60
DMH1	CB6				6.98	0.00	5.00	5.3		N	37.0	16.8	RCP	18	0.061	25.9	-11.1	14.7	98.1	5.96	117.28	111.98	106.02	PRC 3.80
CB6	CB5	0.11	0.95	0.11	8.09	0.00	5.00	5.3	0.57	N	42.9	14.8	RCP	18	0.047	22.7	-20.1	12.9	249.4	11.69	110.82	106.02	94.33	PRC 3.30
CB5	HD1	0.07	0.95	0.06	10.00	0.00	5.00	5.3	0.34	N	53.0	13.4	CMP	18	0.130	20.5	-32.5	11.6	119.0	15.47	99.59	93.84	78.37	PRC 4.25
CB21	CB20	1.87	0.57	1.06	1.06	0.00	5.00	5.3	5.63	Y	5.6	8.6	RCP	12	0.028	5.9	0.3	7.6	21.9	0.61	179.07	175.02	174.41	OK 3.05
CB20	CB18	2.52	0.59	1.49	2.56	0.00	5.00	5.3	7.91	Y	13.5	16.6	RCP	12	0.102	11.4	-2.2	14.5	177.9	18.09	179.07	174.11	156.02	PRC 3.96
CB18	DMH4	0.20	0.69	0.14	2.77	0.00	5.00	5.3	0.75	N	14.7	10.9	RCP	12	0.044	7.5	-7.2	9.5	47.7	2.09	160.62	155.97	153.88	PRC 3.65
CB15	CB14	2.02	0.55	1.11	1.11	0.00	5.00	5.3	5.88	Y	5.9	4.3	CMP	12	0.023	2.9	-3.0	3.7	21.7	0.50	183.30	180.15	179.65	PRC 2.15
CB14	CB12	1.42	0.58	0.83	1.94	0.00	5.00	5.3	4.38	Y	10.3	16.2	RCP	12	0.100	11.2	1.0	14.3	314.7	31.33	183.55	178.85	147.52	OK 3.70
CB12	DMH2	0.50	0.62	0.31	2.74	0.00	5.00	5.3	1.65	N	14.5	18.4	RCP	12	0.124	12.6	-2.0	16.0	57.7	7.18	151.57	147.07	139.89	PRC 3.50
CB2	CB4	0.12	0.95	0.12	0.12	0.00	5.00	5.3	0.61	N	0.6	3.0	CMP	12	0.026	3.1	2.5	3.9	39.3	1.01	99.46	96.26	95.25	OK 2.20
CB4	CB5	0.01	0.95	0.01	1.91	0.00	5.00	5.3	0.05	N	10.1	2.3	CMP	12	0.007	1.6	-8.5	2.0	8.8	0.06	99.45	94.20	94.14	PRC 4.25
CB1	CB3	2.26	0.51	1.16	1.16	0.00	5.00	5.3	6.15	Y	6.1	1.4	CMP	6	0.006	0.2	-5.9	1.2	42.0	0.26	99.67	96.77	96.51	PRC 2.40
CB3	CB4	1.14	0.55	0.63	1.79	0.00	5.00	5.3	3.32	Y	9.5	14.2	RCP	12	0.076	9.8	0.3	12.5	22.0	1.66	99.61	95.96	94.30	OK 2.65
CB8	CB6	0.80	0.56	0.45	0.45	0.00	5.00	5.3	2.37	Y	2.4	10.3	RCP	12	0.076	9.8	7.5	12.5	58.3	4.45	114.07	110.92	106.47	OK 2.15
CB7	CB6	1.13	0.59	0.67	0.67	0.00	5.00	5.3	3.53	Y	3.5	5.1	RCP	12	0.010	3.5	0.0	4.5	28.0	0.27	110.84	106.84	106.57	PRC 3.00
CB13	CB12	0.95	0.52	0.49	0.49	0.00	5.00	5.3	2.61	Y	2.6	6.3	RCP	12	0.019	4.9	2.2	6.2	22.1	0.41	151.53	147.73	147.32	OK 2.80
CB19	CB18	0.12	0.63	0.07	0.07	0.00	5.00	5.3	0.39	N	0.4	4.2	RCP	12	0.028	6.0	5.6	7.6	21.9	0.62	160.49	156.99	156.37	OK 2.50
CB17	CB16	1.27	0.52	0.66	0.66	0.00	5.00	5.3	3.48	Y	3.5	5.6	RCP	12	0.012	3.9	0.4	4.9	22.0	0.26	160.23	156.08	155.82	OK 3.15
CB10	DMH3	0.09	0.95	0.08	0.08	0.00	5.00	5.3	0.43	N	0.4	3.8	RCP	12	0.018	4.8	4.3	6.1	5.6	0.10	146.36	141.78	141.68	OK 3.58
CB11	DMH3	1.55	0.54	0.84	0.84	0.00	5.00	5.3	4.43	Y	4.4	6.2	RCP	12	0.014	4.3	-0.2	5.4	16.1	0.23	146.61	141.81	141.58	PRC 3.80
CB9	DMH1	0.13	0.84	0.11	0.11	0.00	5.00	5.3	0.6	N	0.6	3.7	RCP	12	0.012	4.0	3.4	5.0	5.7	0.07	117.08	112.00	111.93	OK 4.08




Property Information
 Property ID G1-97
 Location 1 DUGGAN RD



**MAP FOR REFERENCE ONLY
 NOT A LEGAL DOCUMENT**


This data set/map is for planning purposes only and should not be used for larger scale analysis. The Town of Acton shall not be held liable for any use of the data or images shown on this map, nor is any warranty of accuracy expressed. All uses of this data set/map are subject to field verification.



Drainage Improvement Plans


- Overall Drainage Improvement Plans
 - NOI Submittal Plan

Drawing name: P:\Drawings\Duggan Road\Drawings\Proposed Conditions.dwg
Mar 04, 2014 11:04am




SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC	PROPOSED CONDITIONS	
CHECKED: CY	DRAWING NO:	DATE: 12/17/2013
SCALE: 1" = 40'		

Drawing name: P:\Drawings\Duggan Road Drainage\Proposed Conditions.dwg
 Jul 14, 2014 9:54am



SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC		
CHECKED: CY	PROPOSED DRAINAGE	
SCALE: 1" = 5'	DRAWING NO: 1	DATE: 12/17/2013



Certified Abutters List / Affidavit / Notice to Abutters



Town of Acton
472 Main Street
Acton, MA 001720
Telephone 978-929-6621
Fax 978-929-6340

Brian McMullen
Assessor

LOCUS 28 Duggan Rd &
6 Macleod Ln
PARCEL ID G1-298,G1-277-5

Parcel ID	Location	Owner	Co-Owner	Mailing Address	City, ST, ZIP
G1-277-15	28 DUGGAN RD BEHIND	KIM YEON H		28 DUGGAN RD	ACTON, MA 01720
G1-277-4	4 MACLEOD LN	LIANG GANG	YANG XINXING	4 MACLEOD LN	ACTON, MA 01720
G1-277-5	6 MACLEOD LN	RAMACHANDRAN KARTHIKEYAN	SANTHANAKRISHNAN HEMA	6 MACLEOD LN	ACTON, MA 01720
G1-277-6	8 MACLEOD LN	MORAN ROBERT J	MORAN GINA E	8 MACLEOD LN	ACTON, MA 01720
G1-286	25 DUGGAN RD	FOLEY MARK	FOLEY DEBORAH	25 DUGGAN RD	ACTON, MA 01720
G1-287	26 DUGGAN RD	MYERS STEPHEN F	MYERS KATHLEEN E	26 DUGGAN RD	ACTON, MA 01720
G1-293	27 DUGGAN RD	KELLOGG KIRK R	JOAN A	27 DUGGAN ROAD	ACTON, MA 01720
G1-297	29 DUGGAN RD	DOWNS GEORGE S TRUSTEE	DOWNS DEANNA K TRUSTEE	29 DUGGAN RD	ACTON, MA 01720
G1-298-1	30 DUGGAN RD	AHERN JR RICHARD B	AHERN LINDA B	30 DUGGAN RD	ACTON, MA 01720
G1-303	32 DUGGAN RD	FAN QUNYING		32 DUGGAN RD	ACTON, MA 01720
G1-310-1	173 WILLOW ST	KERTZNER PETER	KERTZNER JANA	173 WILLOW ST.	ACTON, MA 01720
G1-310-2	32 DUGGAN RD BEHIND	FAN QUNYING	TU QI	32 DUGGAN RD BEHIND	ACTON, MA 01720
G1-310-4	34 DUGGAN RD BEHIND	SULLIVAN DENNIS P	DOREEN	34 DUGGAN RD.	ACTON, MA 01720
G1-310-5	175 WILLOW ST	KNELL MICHAEL	KNELL BIBIANA	179 WILLOW STREET	ACTON, MA 01720
G1-277	167 WILLOW ST	ARNOLD KATHERINE F		167 WILLOW ST	ACTON, MA 01720
G1-277-12	9 MACLEOD LN	TANIMURA TETSUAKI	TANIMURA MAO	9 MACLEOD LN	ACTON, MA 01720
G1-277-13	7 MACLEOD LN	MORANO MICHAEL ANGELO III	CHOI WAN YU	7 MACLEOD LN	ACTON, MA 01720
G1-277-14	3 MACLEOD LN	WEITZNER BARRY D	POMPILIO GRACE L	3 MACLEOD LANE	ACTON, MA 01720
G1-277-16	4 MACLEOD LN BEHIND	BEALS THOMAS P	ZHANG JEAN X	171 WILLOW STREET	ACTON, MA 01720
G1-277-7	10 MACLEOD LN	KAPPEL GARY S	HERTHER KAREN J	10 MACLEOD LANE	ACTON, MA 01720
G1-298	28 DUGGAN RD	KIM YEON H		28 DUGGAN RD	ACTON, MA 01720
G1-310-1	173 WILLOW ST	KERTZNER PETER	KERTZNER JANA	173 WILLOW ST.	ACTON, MA 01720

The owner of land sharing a common boundry or corner with the site of the proposed activity (100 feet) in any direction, including land located directly across a street, way, creek, river, stream, brook or canal. The above are as they appear on the most recent applicable taxes.

13-Jun-14

Kelly Schorr
Acton Assessors Office

**NOTIFICATION TO ABUTTERS
UNDER THE MASSACHUSETTS WETLANDS PROTECTION ACT
AND THE TOWN OF ACTON WETLANDS BYLAW**

In accordance with the second paragraph of Massachusetts General Laws Chapter 131, Section 40 and the Town of Acton Bylaws, you are hereby notified of the following:

The Applicant: Town of Acton

Address 472 Main Street Phone: 978-929-6630

has filed a Notice of Intent with the Acton Conservation Commission seeking permission to remove, fill, dredge or alter an Area Subject to Protection under the Wetlands Protection Act .

Applicant's Representative: Corey York, Town of Acton Engineering Department

Address 472 Main Street Phone: 978-929-6630

The address of the property where the activity is proposed Behind 26 Duggan Road

Town Atlas Plate/Map G-1 Parcel/Lot 26

Project Description Proposed drainage improvements on Duggan Road

Copies of the Notice of Intent may be examined at the Conservation Office, Acton Town Hall, 472 Main Street, Acton. Between the hours of 9:00 A.M. and 4:30 P.M. Monday through Friday. For more information please call the Conservation Office at 978-264-9631.

A Public Hearing will be held at the Acton Town Hall, 472 Main Street, on Wednesday,
8/6/14 at 7:50 P.M.
(date)


The notice of the public hearing, will be published at least five (5) days in advance in the Acton edition of the *Beacon* newspaper or *Metrowest Daily News*.

NOTE: You may also contact your local conservation commission or the nearest Department of Environmental Protection Regional Office for the information about this application or, the Wetlands Protection Act. Acton is in the Central Region. To contact DEP, call:

***Central Region: 508-792-7650**
Southeast Region: 508-946-2800

Northeast Region: 978-661-7600
Western Region: 413-784-1100


USGS Map



Google earth



**NHESP Estimated Habitats of Rare Wildlife & Priority Habitats of Rare Species
OLIVER MassGIS Map**



Available Data Layers

- NHESP Priority Habitats of Rare Species
 - Natural Heritage Data
 - BioMap2
 - NHESP Ecoregions
 - NHESP Certified Vernal Pools
 - NHESP Estimated Habitats of Rare Wildlife
 - NHESP Natural Communities
 - NHESP Priority Habitats of Rare Species
 - Potential Vernal Pools
 - Office of Fishing and Boating Access Sites
 - Openspace
 - The Scenic Landscape Inventory
 - Trails
 - Cultural Resources

Active Data Layers

Check all Uncheck all Remove all

- NHESP Priority Habitats of Rare Species
- Areas of Critical Environmental Concern ACECs
- USGS Quads Last Revised
- USGS 25K Water Bodies
- Tax Parcels for Query
- Detailed Features
- Tax Parcels
- Structures

Legend

NHESP Priority Habitats of Rare Species

-

Areas of Critical Environmental Concern ACECs

-

Tax Parcels for Query

Drainage Improvement Plans



DUGGAN RD

EX CB-3
RIM = 99.61
INV IN (EX CB-1) = 96.51
INV OUT (EX CB-4) = 95.96
INV IN (EX CB-1) = 95.96

12" RCP
L = 41.96'
S = 0.037

INV OUT (CB-3) = 97.50
EX CB-1
RIM = 99.67
INV IN (DRIVEWAY) = 96.82
INV OUT (EX CB-3) = 96.77

ADD DOUBLE CATCH
BASIN RIM (TYP)

12" RCP
L = 21.98'
S = 0.076

REMOVE DRAINAGE
SWALE IN THIS AREA

12" RCP
L = 39.25
S = 0.026
MATCH EXISTING INVERTS

EX CB-2
RIM = 99.46
INV IN (DRIVEWAY) = 96.80
INV OUT (EX CB-4) = 96.26
ADD BIT CONC CURB. SEE CURB PLAN FOR
LIMITS. ADD GUTTER INLETS AT ALL
CATCH BASIN LOCATIONS


24" RCP
L = 249.37'
S = 0.047
MATCH EXISTING INVERTS

EX CB-5
RIM = 99.59
INV IN (EX CB-6) = 94.33
INV IN (EX CB-4) = 94.14
INV OUT (EX HEADWALL) = 93.84
INV IN (EX CB-4) = 93.84

18" RCP
L = 8.79'
S = 0.041

EX CB-4
RIM = 99.45
INV IN (EX CB-2) = 95.25
INV IN (EX CB-3) = 94.30
INV OUT (EX CB-5) = 94.20


24" RCP
L = 119.00'
S = 0.130
MATCH EXISTING INVERTS




SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC	PROPOSED DRAINAGE	
CHECKED: CY	DRAWING NO: 1	DATE: 12/17/2013
SCALE: 1" = 5'		

Drawing name: P:\Drawings\Duggan Road\Drawings\Proposed Conditions.dwg
Mar 04, 2014 - 11:04am


Drawing name: P:\Drawings\Duggan Road\Drawings\Proposed Conditions.dwg
 Mar 04, 2014 - 11:05am



SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC	PROPOSED DRAINAGE	
CHECKED: CY	DRAWING NO: 2	DATE: 12/17/2013
SCALE: 1" = 5'		



Drawing name: P:\Drawings\Duggan Road\Drawings\Proposed Conditions.dwg
 Mar 04, 2014 - 11:05am



EX CB-13
 RIM = 151.53
 INV OUT (EX CB-12) = 147.73

12" RCP
 L = 314.72'
 S = 0.100

12" RCP
 L = 22.08'
 S = 0.019

ADD DOUBLE CATCH
 BASIN RIM (TYP)

APPROXIMATE
 WATER LINE

15" RCP
 L = 57.71'
 S = 0.124
 MATCH EXISTING INVERTS

EX CB-12
 RIM = 151.57
 INV IN (EX CB-14) = 147.52
 INV IN (EX CB-13) = 147.32
 INV OUT (EX DMH-2) = 147.07

EX DMH-2
 RIM = 144.74
 INV IN (EX CB-12) = 139.89
 INV IN (EX DMH-3) = 139.89
 INV OUT (EX DMH-1) = 139.89

18" RCP
 L = 33.91'
 S = 0.062

EX CB-11
 RIM = 146.61
 INV OUT (EX DMH-3) = 141.81

EX DMH-3
 RIM = 146.58
 INV IN (EX DMH-4) = 141.43
 INV IN (EX CB-11) = 141.58
 INV IN (EX CB-10) = 141.68
 INV OUT (EX DMH-2) = 141.43

EX DMH-3
 RIM = 146.58'
 INV IN (DMH-3) = 142.00
 INV IN (CB-11) = 141.58
 INV IN (CB-10) = 141.68
 INV OUT (EX DMH-2) = 142.00

EX CB-10
 RIM = 146.36
 INV OUT (EX DMH-3) = 141.78


18" RCP
 L = 210.04'
 S = 0.143


12" RCP
 L = 16.08'
 S = 0.014

12" RCP
 L = 5.55'
 S = 0.018


18" RCP
 L = 103.79'
 S = 0.048

SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC	PROPOSED DRAINAGE	
CHECKED: CY	DRAWING NO: 3	DATE: 12/17/2013
SCALE: 1" = 5'		











Drawing name: P:\Drawings\Duggan Road\Drawings\Proposed Conditions.dwg
Mar 04, 2014 - 11:05am



SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC		
CHECKED: CY	PROPOSED DRAINAGE	
SCALE: 1" = 5'	DRAWING NO: 4	DATE: 12/17/2013





SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC	PROPOSED DRAINAGE	
CHECKED: CY	DRAWING NO: 5	DATE: 12/17/2013
SCALE: 1" = 10'		



Drawing name: P:\Drawings\Duggan Road\Drawings\Proposed Conditions.dwg
 Mar 04, 2014 - 11:05am

Drawing name: P:\Drawings\Duggan Road\Drainage\Proposed Conditions.dwg
 Mar 04, 2014 - 11:06am



SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC	PROPOSED DRAINAGE	
CHECKED: CY	DRAWING NO: 6	DATE: 12/17/2013
SCALE: 1" = 5'		



WINDEMERE


EX CB-23
RIM = 178.59
INV OUT (EX CB-22) = 174.59

12" RCP
L = 393.87'
S = 0.047

12" RCP
L = 22.01'
S = 0.012


ADD BIT CONC CURB. SEE CURB PLAN FOR LIMITS. ADD GUTTER INLETS AT ALL CATCH BASIN LOCATIONS

EX CB-22
RIM = 178.57
INV IN (EX CB-23) = 174.32
INV OUT (EX CB-16) = 174.07




SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC		
CHECKED: CY	PROPOSED DRAINAGE	
SCALE: 1" = 5'	DRAWING NO: 7	DATE: 12/17/2013


Drawing name: P:\Drawings\Duggan Road\Drawings\Proposed Conditions.dwg
Mar 04, 2014 11:06am




WINDEMERLE DRIVE



SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC		
CHECKED: CY	PROPOSED DRAINAGE	
SCALE: 1" = 5'	DRAWING NO: 8	DATE: 12/17/2013




- NOTES:
- ALL CURBING TO BE BITUMINOUS CONCRETE CURBING
 - ALL CATCH BASIN INLETS TO HAVE GRANITE CURB INLET (SEE DETAILS)
 - DIRECT CURB TO MAXIMIZE STORMWATER FLOW TOWARDS CATCH BASIN RIM




SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC	PROPOSED CURBING	
CHECKED: CY	DRAWING NO: 9	DATE: 12/17/2013
SCALE: 1" = 60'		

Drawing name: P:\Drawings\Duggan Road\Drawings\Proposed Conditions.dwg
 Mar 04, 2014 - 11:06am



PRECAST CONCRETE 60" DIAMETER DOUBLE CATCH BASIN DETAIL

N.T.S.




NOTES:

1. MANHOLE SHALL BE PRECAST CEMENT CONCRETE MANUFACTURED IN ACCORDANCE WITH ASTM C-478 (4,000 psi) DESIGNED FOR H-20-44 LOADING. MANHOLES SHALL BE 48" DIA. UNLESS OTHERWISE INDICATED ON GENERAL PLANS.
2. SEE GENERAL PLANS FOR PIPE SIZE, LINE AND GRADE.
3. DIAMETER OF MANHOLE SHALL BE REVIEWED BY THE GENERAL CONTRACTOR TO DETERMINE A LEGEND OF STANDARD MANHOLE DIMENSIONS WITH RESPECT TO PROPOSED PIPE SIZES, NUMBER AND GEOMETRY. OVER SIZE MANHOLES SHALL BE PROVIDED IF MINIMUM 6" WALL DIMENSION BETWEEN PIPES IS NOT MANUFACTURED.


PRECAST CONCRETE DRAIN MANHOLE

N.T.S.



PRECAST CEMENT CONCRETE CURB

N.T.S.




GUTTER INLET

DATE OF ISSUE

MARCH 2012

DRAWING NUMBER


E 204.2.0



NOTE:
IN CASES WHERE 3/4" STONE IS USED FILTER FABRIC MUST BE INSTALLED AROUND ENTIRE PERIMETER OF STONE MATERIAL.


DRAIN PIPE BEDDING DETAIL

N.T.S.




PRECAST CONCRETE CATCH BASIN DETAIL

N.T.S.



CATCH BASIN FRAME AND GRATE DETAIL

N.T.S.



DOUBLE CATCH BASIN FRAME AND GRATE

N.T.S.

SURVEY: PVC/QRP	TOWN OF ACTON ENGINEERING DEPARTMENT	
DESIGN: PVC	DUGGAN ROAD DRAINAGE SYSTEM	
DRAFTING: PVC		
CHECKED: CY	DETAILS	
SCALE: N.T.S.	DRAWING NO: 10	DATE: 12/17/2013

Photographs

Outlet at 28 Duggan Road

Note: Photograph incorrectly states "18-inch outlet". Outlet is 15 inches



Photographs

Flooding at 171 & 173 Willow Street