



February 29, 2016

Chairman  
**Town of Acton Planning Board**  
472 Main Street  
Acton, MA 01720

**RE: Site Plan Review Application**  
**2798.820 kW Ground Mounted PV Facility**  
**APN H1 Lot 6**  
**Acton, Massachusetts**

Dear Chairman:

Borrego Solar Systems is pleased to submit our Notice of Intent to the Acton Planning Board for the above referenced project. We understand that the solar project is required to go through Site Plan Special Permit process as described under section 3.6.6 "Industrial Ground mount" of the Zoning Bylaws. The following information is attached:

- Eleven (11) 11 x 17 reduced size copies of the Site Plans
- Two (2) full size size copies of the Site Plans + one (1) electronic version
- Two (2) copies of the Stormwater Management Report
- Eleven (11) copies of application
- Certified Abutters List
- Check # 1993 (\$100.00) made payable to the Town of Acton

We respectfully request to present our site plan review application to the Acton Planning Board at the next regularly scheduled hearing in March/April 2016. Please contact me at 978-513-2621 if you have any comments.

Sincerely,

David Albrecht, PE  
Principal Civil Engineer

Attachments



## Description of Work:

The project characteristics are:

- 10.3 acres within fenced area
- 7,668 - 365 w LG Electronics modules
- 25° Tilt Angle
- 32- Sungrow inverters
- 3,433 lf- 6 foot chain link fence w/3 strands barb wire
- 650 lf – 16 foot wide gravel road
- Transformer
- Switchgear
- Data acquisition system (DAS)



Figure 1-RBI Racking





Figure 2-RBI Racking



Figure 3-RBI Racking






Photo #1 – Existing Conditions aerial looking northwesterly.



Photo #2 – Looking southwesterly along proposed interconnection route





**Photo #3 – Looking westerly down pole line route. Town line to the left.**



**Photo #4 – Broken culvert along pole line route.**