

From: [Robert Hart](#)
To: [Kristen Guichard](#)
Cc: [Planning Department](#)
Subject: RE: Munis link: Permit Application 2671
Date: Thursday, July 14, 2016 10:43:48 AM

Kristen,

Sprinklering the garage would be acceptable, in this case, to reduce the required pavement width. However 20 feet remains a requirement as I see it.

Respectfully,

Robert

From: Kristen Guichard
Sent: Thursday, July 14, 2016 10:25 AM
To: Robert Hart
Cc: Planning Department
Subject: RE: Munis link: Permit Application 2671

Hi Robert,

It looks like they would have to shift the structure to the northerly property line and pave the entire southerly side of the lot, this seems like it would be an aesthetically obstructive outcome close to a village center. Is this a case where sprinklering the garage is an acceptable alternative? OR, maybe there are other suggested alternatives?

Thank you so much for your help.

Kristen

Kristen Guichard, AICP
Assistant Town Planner
Town of Acton
472 Main Street
Acton, MA 01720
P: 978-929-6631

From: Robert Hart
Sent: Wednesday, July 13, 2016 10:46 AM
To: Robert Hummel; Building Department; Natural Resources Department; Health Department; Fire Department; Police Department; Manager Department; Design Review Board
Cc: Kimberly Bricker; Planning Department
Subject: RE: Munis link: Permit Application 2671

Robert,