

# Acton Department of Public Health

## Hazardous Material Compliance Inspection Report

J.H  
6/26/08

Name of Facility: Acton WWTF Date: 6/25/08  
Address: 20 Adams St.  
Industry: WWTF Contact Person: John  
Phone: \_\_\_\_\_ Inspector's Name: J. Snair

### Site Condition/Storage/Maintenance

Is the Area visually Clean?

Yes  No

\_\_\_\_\_

Are Spills Present?

Yes  No

gen. fuel oil  
valve leaking

\_\_\_\_\_

Are Materials Appropriately Stored?

Yes  No

\_\_\_\_\_

Are Materials and Waste kept separate?

Yes  No

\_\_\_\_\_

Are Spill Cleanup Materials Available?

Yes  No

Materials Have 110% Secondary Containment:

Yes  No

Are Materials/Wastes Labeled Properly?

Yes  No

Are Any Materials/Wastes Present on Site  
Not Currently Registered With B.O.H.

Yes  No

\_\_\_\_\_

## Safety

Are MSDS's Available On Site?

Yes  No

Is Employee Personal Protective Equipment Available On Site?

Yes  No

Are Employees Trained in Hazardous Materials Handling?

Yes  No

Are Emergency Procedures Posted

Yes  No

## Site Management

Are any Wastes Generated?

Yes  No

If Yes, Are Wastes Removed By a Licensed Hauler?  Yes  No

Name

Phone

Are Throughput Records Available?

Yes  No

Are Any Issues Found in Throughput Records?

Yes  No

*actor transfer station*

Are Floor Drains Present in Any Area with Hazardous Materials or Wastes?

Yes  No

Are Sinks Present in Any Area with Hazardous Materials or Wastes?

Yes  No

Is Testing of the Septic System Necessary?

Yes  No

Does the Site Plan Reflect Current Arrangement?  Yes  No

Any U.S.T. Present?

Yes  No

If Yes, is U.S.T. alarmed?  Yes  No

Any A.S.T. Present?

Yes  No

If Yes, A.S.T has/is:  
(check all that apply)

Secondary Containment   
Stable   
Impervious Base


### Action Items

---

valve leaking: fixed while  
threat

Is a Re-inspection Required?

Yes  No



Inspector's Signature

ACTON WWTP WASTE OIL DISPOSAL

The Acton Wastewater Treatment Facility is disposing of 10 gallons of waste oil generated by oil changes from the plant and pump station equipment. (Blowers, pumps, and landscaping machinery) The oil will be brought to the Acton Transfer Station, where they collect oil. John Parkhurst, the Acton WWTP manager, will be transporting the oil in two five gallon containers to the Acton Transfer station. Bob Mallard, the Acton Transfer Station Attendant, will be receiving the 10 gallons of oil.

Amount of waste oil: 10 gallons

Acton Wastewater Manager: John Parkhurst

Signature/Date:

*John Parkhurst* 4/22/08

Acton Transfer Station Attendant: Bob Mallard

*Bob Mallard*  
Signature/ Date: 4/22/08

5/1/2008

Expires 5/1/09

Paid: Waived

**TOWN OF ACTON  
PERMIT  
HAZARDOUS MATERIALS CONTROL BYLAW  
Acton WWTF,  
20 Adams St Acton, MA 01720**

Is hereby granted a permit to store and use Hazardous Materials at **20 Adams St** Acton, MA 01720. This permit is granted with the conditions as noted on the attached list of conditions assigned to your facility.

Permit Categories:    ,,,

\*See below explanation of permit categories

**HAZARDOUS MATERIALS CONTROL PERMIT CATEGORIES AND FEES**

<u>Category</u>	<u>Initial</u>	<u>Renewal</u>
1. Large Hazardous Waste Generator	\$160	\$65
2. Small Hazardous Waste Generator	\$60	\$45
3. Hazardous Materials Generator	\$160	\$65
4. Hazardous Materials User	\$50	\$45
5. Remediation Discharge Permit	\$575	\$140
6. Remediation Permit	\$595	\$140
7. Hazardous Waste User	\$160	\$65
8. Hazardous Materials Storer Large Industry	\$510	\$235
9. Hazardous Materials Storer Small Industry	\$360	\$160
10. Hazardous Materials Storer Large Retail	\$430	\$140
11. Hazardous Materials Storer Small Retail	\$305	\$160
12. Hazardous Waste Storer Small Industry	\$160	\$65
13. Hazardous Waste Storer Retail	\$60	\$45
14. Hazardous Waste Storer Large Industry	\$160	\$65